

April checklist 2021

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

12347 10685 THERMOSTATS

12348 10686

SITE AND BLDG #: ny116 12349 10687

MECHANIC
SIGNATURE: Ramon V

DATE: 4-7-2021

LOCATION/RM #: WO# 12350 ASSET # 10688
12351 10689

START TIME: FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	yes		thermostat ok
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	yes		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) If it is EMS controlled 1-We log into computer with user name and password for EMS or DDC obtained from site personnel.	yes		
2	2-Validate set point and actual temp at computer	yes		
3	Review all zone set points at the server IF Applicable	yes		
4	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	yes		
5	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	yes		
6	If applicable, replace battery as needed.	yes		
	Use our own Temperature meter to validate the computer is correct. If it is not EMS or DDC controlled take our temperature meter and check against actual thermostat and record temperature	yes		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: