

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **UNIT HEATER, HOT WATER**

SITE AND BLDG #: **Gaithersburg MD013**

LOCATION/RM #: **Kitchen** **WO#** **ASSET #** **13733**

bldg 1

MECHANIC **DATE:** **3/8/21**

SIGNATURE:  **START TIME:** **12:50** **FINISH TIME:** **1:25**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Schedule shutdown with operating personnel.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	✓		
2	Clean the coil with vacuum cleaner.	✓		
3	Comb the fins as needed.	✓		
4	Clean all fans and motors.	✓		
5	Check operation of controls and safeties.	✓		
6	Lubricate as required.	✓		
7	Check all motors, belts, pulleys, shafts, etc. for alignment.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: