

SITE AND BLDG #:		Rockville MD021	
LOCATION/RM #:		Bldg 1	WO# 14006
MECHANIC SIGNATURE:			
DATE:		5/7/21	
START TIME:	9:20	FINISH TIME:	10:10

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	✓		
2	Initial and Date Filter (if disposable)	✓		
3	Initial and Date Yellow Maintenance Tag (if applicable)	✓		
ASSET #	SIZE	QTY		NOTES/ ACTIONS
2098	Record Size : not in use			
2099	not in use			
2101	16x25x2 (1) 16x20x2 (1)	2		
2108	16x20x4 (2) 20x25x2 (4)	6		
NOTE : Any AHU with outside air -Filter gets replaced Quarterly				
All other filters get replaced annually But inspected Quarterly				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: