

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
DOMESTIC HOT WATER HEATER - GAS

SITE AND BLDG #: **White Plains MD066**

MECHANIC  
SIGNATURE: 

DATE: **4/23/21**

LOCATION/RM #: **bldg 2** WO# **14112** ASSET # **552**

START TIME: **9:55**

FINISH TIME: **10:20**

| CHECK POINT                                | CHECKPOINT DESCRIPTION                                                                                                                                                                           | TASK COMPLETE |    | NOTES/ ACTIONS<br>(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)             |
|--------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|----|-------------------------------------------------------------------------------------|
|                                            |                                                                                                                                                                                                  | YES           | NO |                                                                                     |
| SPECIAL INSTRUCTIONS                       |                                                                                                                                                                                                  |               |    |                                                                                     |
| 1                                          | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.                                      | ✓             |    |                                                                                     |
| 2                                          | Use caution when working with natural gas fired equipment. Be aware of any smells (rotten egg) that could be a natural gas leak.                                                                 | ✓             |    |                                                                                     |
| 3                                          | Do not allow any open flames around equipment.                                                                                                                                                   | ✓             |    |                                                                                     |
| TO BE PERFORMED AT EACH INSPECTION SERVICE |                                                                                                                                                                                                  |               |    |                                                                                     |
| 1                                          | Attach drain hose. Drain several gallons from tank to remove sediment.                                                                                                                           | ✓             |    |                                                                                     |
| 2                                          | Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge. | ✓             |    |                                                                                     |
| 3                                          | Check all connections - electric, gas and water. Tighten as necessary.                                                                                                                           | ✓             |    |                                                                                     |
| 4                                          | Check operation and setting of aquastat. Check hot water temperature with dial thermometer, and set aquastat at minimum value required for all uses.                                             | ✓             |    |                                                                                     |
| 5                                          | Clean Water heater shell and Report any leaks.-Open CM                                                                                                                                           | ✓             |    |  |
| 6                                          | Clean pump, controls, switches, and starters. Check operation of pump and condition of pump seal or packing, and replace as required.                                                            | ✓             |    |                                                                                     |
| 7                                          | If applicable, Remove and inspect Anode, replace if necessary                                                                                                                                    | ✓             |    |                                                                                     |
| 8                                          | Clean up work area and remove trash.                                                                                                                                                             | ✓             |    |                                                                                     |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**