

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
KITCHEN HOOD

ACTIVITY AND BLDG #: Gaithersburg MD013

**MECHANIC
SIGNATURE:**



DATE: 6/1/21

LOCATION/RM #: kitchen **WO#** 14Z3U **ASSET #** 1167&1168

START TIME: 9:30

FINISH TIME: 10:05

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean all accessible surfaces thoroughly.	✓		
2	Check all louvers and dampers. If dampers must be moved to ensure complete cleaning, ensure they will be marked and returned to their original position to prevent unbalancing the system.	✓		
3	Clean and/or replace filters, if applicable.	✓		
4	Enure unit is operating properly, not any deficiencies.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: