

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **GREASE TRAP**

SITE AND BLDG #: **Rockville MD021**


MECHANIC
SIGNATURE: 

DATE: **6/3/21**

LOCATION/RM # **exterior of WO# 14269** ASSET # **1556**
kitchen

START TIME: **7:30**

FINISH TIME: **7:40**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
2	Insure proper grease disposal.-Tanks are pumped by local septic companies	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
2	Remove lid. If the trap is equipped with removable baffles, remove them.	✓		
3	Make sure the flow restrictor on the inflow pipe is present.	✓		
4	If damages, missing parts, or cleaning is required, report them as needed to ensure proper working operation.	✓		
5	Replace lid and baffles.	✓		
6	Return (or fill) water to grease trap	✓		
7	Record grease trap maintenance activities on your log or request a receipt from your grease hauler. Keep records for 3 years. -In Maximo under W/O#	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: