

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **FILTER REPLACEMENT**

SITE AND BLDG #: **White Plains MD066** MECHANIC SIGNATURE:  DATE: **7/27/21**

LOCATION/RM#: **throughout WO# 14587 building 1** START TIME: **8:00** FINISH TIME: **3:00**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	✓		
2	Initial and Date Filter (if disposable)	✓		
3	Initial and Date Yellow Maintenance Tag (if applicable)	✓		
ASSET #	SIZE	QTY		NOTES/ ACTIONS
101-166	Record Size : 18x18x1	65		
176	20x25x4	6		
186	20x20x4	16		
286	20x20x4	2		
287	cleanable filter	1		
288 (2)	20x20x2	6		
321 (2)	24x16x1	1		
325 (2)	24x16x1	1		
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: