

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**DEHUMIDIFIER**

**SITE AND BLDG #:** Gaithersburg MD013

**MECHANIC SIGNATURE:** 

**DATE:** 10/12/21

**LOCATION/RM #:** weapons **WO#** 15074 **ASSET #** 1998  
**vault**

**START TIME:** 1:00

**FINISH TIME:** 1:05

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check water inlet and outlet for any leaks, repair as needed.			
2	Clean and/or replace filter as needed. -Record space humidity			 Space Humidity <u>31%</u> %
3	If applicable, check hours per usage, replace tanks as needed.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**