

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 12/20/21

Contractor Personnel on Site:

1. PATRICK BROWN 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 15221 , 15222 , 15289 , 15290 , 15340 , 15341 ,
2. 15493 , 15521 , 15223 , 15224 , 15311 , 15342 , 15343 , 15522 ,
3. ASSET#'S , 10035 , 10036 , 10066 , 10069 , 10042 , 10065 ,
4. 10073 , 10077 , 10080 , 10075 , 10076 , 190917- , 294 , 299 ,
5. 292 , 293 , 297 , 298 , 300 , 303 , 304 , 305 , 306 ,

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 12/20/21

Signed: 

To be signed by Facility Manager:


By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC ERIC ABBOTT Date: 12/20/21

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GATES

SITE AND BLDG #: **NY051 BLDG1**LOCATION/RM #: **BLDG1** WO# **15290**, ASSET # **10069**
15493, 190917-MECHANIC
SIGNATURE: DATE: **12/20/21**START TIME: **9:30am**FINISH TIME: **10am**

CHECK POINT	CHECKPOINT ID/ OPTION	297-299	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
			YES	NO	
SPECIAL INSTRUCTIONS					
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	/	
2	Notify affected personnel before performing PM		✓	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Inspect all pivot points, hinges, latches, etc. Apply lubricant where needed, wiping off excess.		✓	/	used PB blaster garage door lubricant
2	Check all locking devices. Lubricate as required.		✓	/	all are good
3	Inspect gate support rollers and track, lubricate and clean as required.		✓	/	used white lithium grease
4	Check bolts, fasteners, and mounting hardware. Tighten as necessary.		✓	/	all are tight
5	Check for any obstructions that prevent full swing or movement of the gate.		✓	/	no obstructions
6	Check that shrubs and trees are pruned clear of gate.		✓	/	shrubs and trees are clear of gate
7	Check hold open devices for proper operation. Lubricate as required.		✓	/	
8	Check the top guard and ensure that it is properly fastened and the wires are tight. Tighten as required.		✓	/	top gaurd and wires are tight
9	If applicable, inspect hydraulic driveline (hoses, fittings, and gauges) for signs of leakage.		✓	/	no hydraulics
10	If applicable, inspect limit switches for proper operation. Adjust as needed.		✓	/	limit switches are correct
11	If applicable, inspect photoeyes for proper operation and any signs of damage.		✓	/	no sign's of damage
12	If applicable, have site personnel operate gate with CAC Card insuring proper operation.		✓	/	gate functions properly with card
13	If applicable, clean control cabinet, ensuring free from debris and insects.		✓	/	no debris or insects

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be perfomed by: General Maintenance Worker

there is a capital project submitted to have all the gates replaced
asset# 190917-299 does not function at all