

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: Gaithersburg MD013


**MECHANIC
SIGNATURE:** 

DATE: 10/12/21

LOCATION/RM #: MEP lot **WO#** 15305 **ASSET #** 3Y262

START TIME: 6:00

FINISH TIME: 6:10

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO		
SPECIAL INSTRUCTIONS					
1	Schedule and coordinate work with operating personnel.	✓			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Inspect lighting contactor for pitting or arcing -report issues	✓			
2	Inspect visual condition of wiring. Look for evidence of overheating.	✓			
3	Check for proper light operation.	✓			
4	Test operation of automatic switches/ time clock/ photocells if applicable.	✓			
5	Inspect light pole and mounting devices for deficiencies.	✓			
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: **one light out in fenced area behind building. ticket in system.**