

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 12/20/21

Contractor Personnel on Site:

1. PATRICK BROWN 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 15221 , 15222 , 15289 , 15290 , 15340 , 15341 ,
2. 15493 , 15521 , 15223 , 15224 , 15311 , 15342 , 15343 , 15522 ,
3. ASSET#'S , 10035 , 10036 , 10066 , 10069 , 10042 , 10065 ,
4. 10073 , 10077 , 10080 , 10075 , 10076 , 190917- , 294 , 299 ,
5. 292 , 293 , 297 , 298 , 300 , 303 , 304 , 305 , 306 ,

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 12/20/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC ERIC ABBOTT Date: 12/20/21

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, INFRA-RED, RADIANT, GAS

SITE AND BLDG #: NY051 BLDG2
LOCATION/RM #: maintenance bay **WO#** 15342 **ASSET #** 10075

MECHANIC
 SIGNATURE:

DATE: 12/20/21

START TIME: 12:30pm

FINISH TIME: 1pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	For gsa/oil heaters: 1. Remove access panels if applicable. 2. Check the fire box liner or refractory for cracks and leaks. 3. Check all gas lines for leaks. Repair as needed.	✓		all are good
2	Clean dirt from heater, vaccuming is preferred.	✓		heater is clean
3	Check operation of gas valve.	✓		gas valve functions properly
4	Check for gas leaks.	✓		no gas leaks found
5	Check operation of thermostat.	✓		thermostat functions properly
6	If applicable, replace primary air intake filter.	✓		filters are new
7	As needed, clean spark electrode and reset gap, replace if necessary.	✓		electrode is good
8	Inspect flue pipe and connections.	✓		connections are good no leaks
9	If applicable, inspect and clean outside air blower and blower intake.	✓		blower is clean
10	Inspect unit for proper operation.	✓		unit functions properly
11	Inspect unit for overall condition and recommend for replacement or other needed repairs.	✓		no needed repairs

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: