

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GLYCOL TANK

SITE AND BLDG #: White Plains MD066

**MECHANIC
SIGNATURE:**

DATE: 12/15/21

LOCATION/RM #: mech. rm. **WO#** 15923 **ASSET #** 177

START TIME: 8:15

FINISH TIME: 8:30

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Examine exterior of tank, including fittings, gauges, structural supports, manholes, and handholes for leaks, signs of corrosion, or other defects.	✓		
2	Clean, test and inspect sight glasses, valves, fittings, drains, and controls.	✓		
3	Check condition of agitators and/or float assemblies.	✓		
4	If applicable, clean strainer(s).	✓		
5	Clean up work site.- Report any issues	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: