


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

SITE AND BLDG #: **Rockville MD021**

MECHANIC
SIGNATURE:  DATE: 2/8/22

LOCATION/RM #: **Bldg 1** **WO#** **16287**

START TIME: 9:00 **FINISH TIME:** 9:45

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	✓		
2	Initial and Date Filter (if disposable)	✓		
3	Initial and Date Yellow Maintenance Tag (if applicable)	✓		
ASSET #	SIZE	QTY		NOTES/ ACTIONS
2098	Record Size : not in use			
2099	not in use			
2101	16x25x2 (1) 16x20x2 (1)	2		
2108	16x20x4 (2) 20x25x2 (4)	6		
				 
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: