

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

SITE AND BLDG #: Alexandria VA002




**MECHANIC
SIGNATURE:**

DATE: 2/28/22

LOCATION/RM #: Drill Hall **WO#** 16289

START TIME: 8:20

FINISH TIME: 8:30

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.			
2	Initial and Date Filter (if disposable)			
3	Initial and Date Yellow Maintenance Tag (if applicable)			
ASSET #	SIZE	QTY		NOTES/ ACTIONS
2185	Record Size : 16x25x2 (2) 16x20x2 (2)	4		
2186	16x25x2 (2) 16x20x2 (2)	4		units not in use due to Drill Hall a unconditioned space.Filters and units are clean.
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: