

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, HOT WATER

SITE AND BLDG #: Gaithersburg MD013

LOCATION/RM #: Kitchen WO# 16672 ASSET # 1990
bldg 1


MECHANIC
SIGNATURE: 

DATE: 3/1/22

START TIME: 9:35

FINISH TIME: 10:10

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO. PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Schedule shutdown with operating personnel.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for signs of abnormal wear and leaks. Replace packing if needed.			
2	Clean the coil with vacuum cleaner.			
3	Comb the fins as needed.			
4	Clean all fans and motors.			
5	Check operation of controls and safeties.			
6	Lubricate as required.			
7	Check all motors, belts, pulleys, shafts, etc. for alignment.			



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: