

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VAV BOX

SITE AND BLDG #: **White Plains MD066**


**MECHANIC
SIGNATURE:**

DATE: **3/14/22**

LOCATION/RM #: **Bldg. 1 wo# 16737 ASSET # 309-31820**

START TIME: **11:05**

FINISH TIME: **11:55**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		checklist is for dampers
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS system permits, check that the operating controls activate damper per design specifications.-	<input checked="" type="checkbox"/>		Record CFM AIR FLOW _____
2	If required, check damper linkage for tightness and lightly lubricate.	<input checked="" type="checkbox"/>		
3	If required, inspect dampers for free movement.	<input checked="" type="checkbox"/>		
4	If required, inspect actuators for tightness to mounting brackets.	<input checked="" type="checkbox"/>		
5	As needed, tighten electrical connections to servo motor.	<input checked="" type="checkbox"/>		
6	Inspect unit for overall condition and recommend for replacement or other needed repairs.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: