

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**MISCELLANEOUS KITCHEN EQUIPMENT**

**ACTIVITY AND BLDG #:** **Saugerties 128**


**MECHANIC  
SIGNATURE:**

**DATE:** **1/4/2023**


**LOCATION/RM #:** **kitchen**



**WO#**



**ASSET #**



**START TIME:** **0830**

**FINISH TIME:** **1300**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Notify cafeteria operator and get permission prior to performing all maintenance.	✓		mixer missing screws beverage dispenser missing parts
2	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
3	De-energize, lock out, and tag electrical circuits and fuel service.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check with operator or manager for any deficiencies, verify cleaning program.	✓		
2	Check all controls, mechanisms for proper operation; adjust as required.	✓		
3	If applicable, examine utility supply line, piping, valve packing, specialties, and insulation; look for any leaks.	✓		
4	If applicable, check electric power line condition, switch, disconnect, etc.; or check condition of gas supply, valves, regulators, and inspect pilot, check for Gas leaks.	✓		
5	Ensure unit is clean and in working order. Note any deficiencies.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**