

**Inspection Report for Oil and Water Separator Located
at 1001 Ogletown Road, Newark, DE 19711**

April 15, 2022


AEG Environmental cleaned and inspected the Oil and Water Separator (OWS) located at 1001 Ogletown Road, Newark, DE on April 15, 2022. AEG arrived on site at approximately 0815 and opened the OWS. No cracks, breaks or other deficiencies were observed in any of the OWS chambers. Several of the bolts holding the covers on the OWS had to be broken to remove the lid and should be replaced. AEG removed liquids and solid waste from the chambers of the OWS. Approximately 1000 gallons of waste were collected from the system for disposal. No deficiencies were observed in any of the OWS chambers. Photographic evidence is attached to this document.



Vault, Pre Pump Out



Vault, Pre Pump Out



Vault being pumped



Vault Being pumped out



Vault Pumped Out