

Fire Suppression Inspection Certificate

For

Tidewater - USARC 99th -
Bridgeport WV010
Rt 2 Box 77
Meadowbrook Road
Bridgeport, WV 26330

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Date
May 1, 2024

Building: Tidewater - USARC 99th - Bridgeport WV010
Contact: Jennifer Bailie
Title: Manager

Company: Brewer and Company
Contact: Hunter Mouse
Title: Alarm Tech

Executive Summary

Generated by: BuildingReports.com

Building Information

Building: Tidewater – USARC 99th – Bridgeport WV010	Contact: Jennifer Bailie
Address: Rt 2 Box 77	Phone: 724.544.5252
Address: Meadowbrook Road	Fax:
City/State/ZIP Code: Bridgeport, WV 26330	Mobile:
Country: United States of America	Email: jennifer.a.bailie.ctr@mail.mil

Inspection Performed By

Company: Brewer and Company	Inspector: Hunter Mouse
Address: 3601 7th Avenue	Phone: 681.867.8996
Address:	Fax:
City/State/ZIP Code: Charleston, WV 25387	Mobile:
Country: United States of America	Email: hunter.mouse@brewerfire.com

System Control Unit

Manufacturer: Ansul	Discharge Time:	Predischarge Delay:
Model Number: R-102	Install Date: 12/15/2020	
Software Version:	Version Date: 12/15/2020	
Location: Kitchen	Current Protection:	

Systems Inspected

System Type	Protected Area	Devices
Kitchen	Range Hood-	6

Inspection Summary

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Container	3	50.00%	3	100.00%	3	100.00%	0	0.00%
Controls	1	16.67%	1	100.00%	1	100.00%	0	0.00%
Initiating	2	33.33%	2	100.00%	2	100.00%	0	0.00%
Totals	6	100%	6	100.00%	6	100.00%	0	0.00%

Certification

Company: Brewer and Company	Building: Tidewater – USARC 99th – Bridgeport WV010
Inspector: Hunter Mouse	Contact: Jennifer Bailie

Inspection & Testing

Generated by: BuildingReports.com

Building: Tidewater - USARC 99th - Bridgeport WV010

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Kitchen Range Hood-				
CO2 Tank	Kitchen	Tested	1:20:20 PM	05/01/2024
Cylinder	Kitchen	Tested	1:20:23 PM	05/01/2024
Nozzle	Kitchen	Tested	1:20:26 PM	05/01/2024
Control Panel	Kitchen	Tested	1:20:17 PM	05/01/2024
Fusible Link	Kitchen	Tested	1:20:29 PM	05/01/2024
Pull Station	Kitchen	Tested	1:20:14 PM	05/01/2024

Sequence of Operation

Generated by: BuildingReports.com

No devices were found for this section of the report.

Time, Temperature & Level Testing

Generated by: BuildingReports.com

Building: Tidewater - USARC 99th - Bridgeport WV010	All Protected Areas					
<i>The Time, Temperature, & Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level.</i>						
Type						
Type	Location	Comment	Sec	Deg	Lvl	ScanID
<i>Kitchen Range Hood-</i>						
Fusible Link						
K	Kitchen	Passed	n/a	360F	n/a	64974425

Agent Container Report

Generated by: BuildingReports.com

Building: Tidewater - USARC 99th - Bridgeport WV010		All Protected Areas					
<i>A container of stored agent to be used in case of a fire emergency.</i>							
Kitchen Range Hood-							
CO2 Tank							
Type	Location		Serial Number	Hydro			
High Pressure	Kitchen		02/18/2021	64974422			
Capacity	Gross Weight	Actual Weight	Tare Weight	Liquid Level			
				<input type="checkbox"/>			
Cylinder							
Location	Manufacturer	Type	Supply	Size			
Kitchen	Ansul	Wet Chemical	Master	3 gal			
Method	Weight	Pressure	UL 300	Total Flow Points Used			
Mechanical-Automatic			<input type="checkbox"/>				
Install Date	Recharged			Hydro			
02/18/2021	02/18/2021			02/18/2021			
Nozzle							
Quantity	Location		Install Date	Manufacturer			
6	Kitchen		12/15/2008	Ansul			
				64974424			

Kitchen System

Generated by: BuildingReports.com

Building: Tidewater - USARC 99th -
Bridgeport WV010

All Protected Areas

A pre-engineered wet chemical fire-extinguishing system that discharges wet chemical from fixed nozzles and piping by means of expellant gas or a dry chemical fire-extinguishing system that discharges dry chemical from fixed nozzles or hand hose lines by means of expellant gas.

Kitchen Range Hood-

Control Panel

Manufacturer	Location	Model	Serial	Install Date	ScanID
Ansul	Kitchen	R-102	S240084	12/15/2020	64974421

Fusible Link

Temp	Location	Quantity	Type	Manufacturer	Model #	ScanID
360F	Kitchen	3	K	Ansul		64974425

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Tidewater - USARC 99th -
Bridgeport WV010

All Protected Areas

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Item	Category	% of Inventory	Quantity
CO2 Tank	Container	16.67%	1
Control Panel	Controls	16.67%	1
Cylinder	Container	16.67%	1
Fusible Link	Initiating	16.67%	1
Nozzle	Container	16.67%	1
Pull Station	Initiating	16.67%	1

In Service - 3 Years to 5 Years				
Device or Item	Qty	Model #	Description	Install Date
Kitchen Range Hood-				
CO2 Tank	1	101-20 part 17492	High Pressure	02/18/2021
Cylinder	1		Wet Chemical	02/18/2021
Control Panel	1	R-102		12/15/2020
Pull Station	1		Cable	12/15/2020
In Service - 15 Years to 25 Years				
Kitchen Range Hood-				
Fusible Link	1		K	12/15/2008
Nozzle	1			12/15/2008