

# Fire Alarm and Life Safety System Inspection Certificate

*For*

Tidewater - USARC 99th -  
Parkersburg WV046  
4603 Camden Avenue  
Parkersburg, WV 26101

Tested to NFPA 72 Standards

*This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.*

*Inspection Date*  
May 3, 2024

Building: Tidewater - USARC 99th - Parkersburg WV046  
Contact: Jennifer Bailie  
Title: Manager

Company: Brewer and Company  
Contact: Antwon Davis  
Title: Technician(Service & Inspections)

# Executive Summary

Generated by: BuildingReports.com

## Building Information

<b>Building:</b> Tidewater – USARC 99th – Parkersburg WV046	<b>Contact:</b> Jennifer Bailie
<b>Address:</b> 4603 Camden Avenue	<b>Phone:</b> 724.544.5252
<b>Address:</b>	<b>Fax:</b>
<b>City/State/ZIP Code:</b> Parkersburg, WV 26101	<b>Mobile:</b>
<b>Country:</b> United States of America	<b>Email:</b> jennifer.a.bailie.ctr@mail.mil

## Inspection Performed By

<b>Company:</b> Brewer and Company	<b>Inspector:</b> Antwon Davis
<b>Address:</b> 3601 7th Avenue	<b>Phone:</b> 304-744-5314
<b>Address:</b>	<b>Fax:</b>
<b>City/State/ZIP Code:</b> Charleston, WV 25387	<b>Mobile:</b> 304-549-9963
<b>Country:</b> United States of America	<b>Email:</b> antwon.davis@brewerfire.com

## System Control Unit

<b>Manufacturer:</b> Siemens	<b>Inspection Date:</b> 05/01/2024	<b>IDC Style:</b>
<b>Model Number:</b> FHD2009-U1	<b>Install Date:</b> 05/12/2022	<b>SLC Style:</b>
<b>Software Version:</b>	<b>Version Date:</b> 05/12/2022	<b>NAC Style:</b>
<b>Location:</b> 1st FACP	<b>Current Protection:</b>	

## Central Station Signal Verification

<b>Type:</b>	<b>Mfg:</b>	<b>Model #:</b>
<b>Test Time/Date:</b>	<b>Restore Time:</b>	<b>Note:</b>
Type of Signal	Signal Confirmation	Notes
Type:	Confirmed Time:	Note:

Inspection Summary								
Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Control	6	7.50%	6	100.00%	6	100.00%	0	0.00%
Indicating	2	2.50%	2	100.00%	2	100.00%	0	0.00%
Initiating	71	88.75%	71	100.00%	71	100.00%	0	0.00%
Monitor	1	1.25%	1	100.00%	1	100.00%	0	0.00%
<b>Totals</b>	<b>80</b>	<b>100%</b>	<b>80</b>	<b>100.00%</b>	<b>80</b>	<b>100.00%</b>	<b>0</b>	<b>0.00%</b>

## Certification

**Company:** Brewer and Company

**Inspector:** Antwon Davis



Signed: May 3, 2024

**Building:** Tidewater – USARC 99th – Parkersburg WV046

**Contact:** Jennifer Bailie



Signed: May 1, 2024

## Antwon Davis Certifications

Certification Type	Number
Getz Equipment Innovators Certification- NFPA 10 Portable Fire Extinguishers	
ICC/NAFED Pre-Engineered Kitchen Fire Extinguishing Systems Technician	
West Virginia License – Fire Extinguisher Technician	

# Inspection & Testing

Generated by: BuildingReports.com

Building: Tidewater - USARC 99th -  
Parkersburg WV046

Control Panel: 1 - Siemens  
FHD2009-U1

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date
<b>Passed</b>				
<b>Control</b>				
Battery	1st FACP	Tested	11:11:48 AM	05/01/2024
Battery	1st FACP	Tested	11:11:52 AM	05/01/2024
Battery	1st FACP Garage Building	Tested	3:07:26 PM	05/03/2024
Battery	1st FACP Garage Building	Tested	3:07:30 PM	05/03/2024
Control Panel	1st FACP	Tested	11:03:12 AM	05/01/2024
<b>Indicating</b>				
Horn/Strobe	1st ALL HORNS & STROBES	Tested	3:06:02 PM	05/03/2024
Horn/Strobe	1st ALL HORNS & STROBES IN GARAGE BUILDING	Tested	3:07:33 PM	05/03/2024
<b>Initiating</b>				
Heat Detector	1st Assembly room	Visually Checked	3:05:25 PM	05/03/2024
Heat Detector	1st Assembly room	Visually Checked	3:05:29 PM	05/03/2024
Heat Detector	1st Assembly room	Visually Checked	3:05:32 PM	05/03/2024
Heat Detector	1st Assembly room	Visually Checked	3:05:35 PM	05/03/2024
Heat Detector	1st Assembly room storage	Visually Checked	3:05:59 PM	05/03/2024
Heat Detector	1st Front hall janitor closet between restrooms	Visually Checked	3:04:51 PM	05/03/2024
Heat Detector	1st Garage building	Visually Checked	3:06:54 PM	05/03/2024
Heat Detector	1st Garage building	Visually Checked	3:06:57 PM	05/03/2024
Heat Detector	1st Garage building	Visually Checked	3:07:01 PM	05/03/2024
Heat Detector	1st Garage building	Visually Checked	3:07:05 PM	05/03/2024
Heat Detector	1st Garage building	Visually Checked	3:07:09 PM	05/03/2024
Heat Detector	1st Garage building	Visually Checked	3:07:13 PM	05/03/2024
Heat Detector	1st Garage building 102G rear storage next to weights	Visually Checked	3:07:16 PM	05/03/2024
Heat Detector	1st Garage building 102G rear storage next to weights	Visually Checked	3:07:19 PM	05/03/2024
Heat Detector	1st Garage building AMSA 102 side room	Visually Checked	3:06:51 PM	05/03/2024
Heat Detector	1st Garage building hall bathroom	Visually Checked	3:06:32 PM	05/03/2024
Heat Detector	1st Garage building hall bathroom	Visually Checked	3:06:35 PM	05/03/2024
Heat Detector	1st Storage/vault	Visually Checked	3:05:44 PM	05/03/2024
Heat Detector	1st Storage/vault	Visually Checked	3:05:49 PM	05/03/2024
Heat Detector	1st Storage/vault	Visually Checked	3:05:52 PM	05/03/2024
Heat Detector	1st Storage/vault	Visually Checked	3:05:55 PM	05/03/2024
Pull Station	1st Admin rear exit	Tested	3:04:15 PM	05/03/2024
Pull Station	1st Assembly hall kitchen right exit	Tested	3:05:06 PM	05/03/2024
Pull Station	1st Assembly hall left exit	Tested	3:04:59 PM	05/03/2024

Device Type	Location	Service	Time	Date
<b>Passed</b>				
Pull Station	1st Assembly hall rear left exit	Tested	3:05:03 PM	05/03/2024
Pull Station	1st Assembly hall rear left exit	Tested	3:05:22 PM	05/03/2024
Pull Station	1st Assembly hall right exit	Tested	3:04:54 PM	05/03/2024
Pull Station	1st Front hallway doorway	Tested	3:03:20 PM	05/03/2024
Pull Station	1st Garage Building left front exit	Tested	3:06:09 PM	05/03/2024
Pull Station	1st Garage Building left rear exit	Tested	3:06:06 PM	05/03/2024
Pull Station	1st Garage Building rear hall exit	Tested	3:06:26 PM	05/03/2024
Pull Station	1st Garage Building right wall exit	Tested	3:06:12 PM	05/03/2024
Pull Station	1st Garage Building storage exit	Tested	3:06:47 PM	05/03/2024
Pull Station	1st Right side hallway exit	Tested	3:03:44 PM	05/03/2024
Smoke Detector	1st Admin	Tested	3:04:03 PM	05/03/2024
Smoke Detector	1st Admin	Tested	3:04:06 PM	05/03/2024
Smoke Detector	1st Admin office 2	Tested	3:04:37 PM	05/03/2024
Smoke Detector	1st Admin office 6	Tested	3:04:21 PM	05/03/2024
Smoke Detector	1st Admin office 7	Tested	3:04:30 PM	05/03/2024
Smoke Detector	1st Admin office 8	Tested	3:04:18 PM	05/03/2024
Smoke Detector	1st Admin office it room	Tested	3:04:33 PM	05/03/2024
Smoke Detector	1st Admin rear exit	Tested	3:04:10 PM	05/03/2024
Smoke Detector	1st Front hall Career Counselor office	Tested	3:03:59 PM	05/03/2024
Smoke Detector	1st Front hall female restroom	Tested	3:04:47 PM	05/03/2024
Smoke Detector	1st Front hall kitchen	Tested	3:04:40 PM	05/03/2024
Smoke Detector	1st Front hall mens restroom	Tested	3:04:44 PM	05/03/2024
Smoke Detector	1st Front hallway above lamp board	Tested	3:02:23 PM	05/03/2024
Smoke Detector	1st Front hallway above water fountain next to restroom	Tested	3:02:27 PM	05/03/2024
Smoke Detector	1st Front hallway in front of admin entrance	Tested	3:02:20 PM	05/03/2024
Smoke Detector	1st Front hallway in front of assembly hall door	Tested	3:02:31 PM	05/03/2024
Smoke Detector	1st Front hallway office 10	Tested	3:02:34 PM	05/03/2024
Smoke Detector	1st Front hallway office 15	Tested	3:03:14 PM	05/03/2024
Smoke Detector	1st Front hallway office 15	Tested	3:03:17 PM	05/03/2024
Smoke Detector	1st Garage Building hall exit	Tested	3:06:22 PM	05/03/2024
Smoke Detector	1st Garage Building hall exit	Tested	3:06:29 PM	05/03/2024
Smoke Detector	1st Garage Building room 104	Tested	3:06:43 PM	05/03/2024
Smoke Detector	1st Garage Building room 105	Tested	3:06:39 PM	05/03/2024
Smoke Detector	1st Garage Building above FACP	Tested	3:06:19 PM	05/03/2024
Smoke Detector	1st Garage Building mid hall	Tested	3:06:15 PM	05/03/2024
Smoke Detector	1st Inside room 12	Tested	3:03:28 PM	05/03/2024
Smoke Detector	1st Inside room 13	Tested	3:03:31 PM	05/03/2024
Smoke Detector	1st Inside room 14	Tested	3:03:35 PM	05/03/2024
Smoke Detector	1st Left side kitchen in assembly hall	Tested	3:05:15 PM	05/03/2024
Smoke Detector	1st Right Side hall class room A	Tested	2:32:16 PM	05/01/2024
Smoke Detector	1st Right Side hall class room B	Tested	3:03:51 PM	05/03/2024
Smoke Detector	1st Right Side hall class room C	Tested	3:03:48 PM	05/03/2024
Smoke Detector	1st Right Side hall in front of class A	Tested	3:03:54 PM	05/03/2024
Smoke Detector	1st Right Side hall in front of exit	Tested	3:03:40 PM	05/03/2024
Smoke Detector	1st Right side kitchen in assembly hall	Tested	3:05:11 PM	05/03/2024
Smoke Detector	1st Side hall above room 12	Tested	3:03:25 PM	05/03/2024
Smoke Detector	1st kitchen in assembly hall ICE ROOM	Tested	3:05:18 PM	05/03/2024
<b>Monitor</b>				
Monitoring	1st Johnson Controls/Simplex Grinnell	Tested	11:13:28 AM	05/01/2024

Building: Tidewater - USARC 99th -  
Parkersburg WV046

Control Panel: 2 - Siemens  
FHD2009-U1

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
<b>Control</b>				
Control Panel	1st FACP Garage Building	Tested	3:07:23 PM	05/03/2024

# ***Service Summary***

*Generated by: BuildingReports.com*

**Building: Tidewater - USARC 99th - Parkersburg WV046**

*The Service Summary section provides an overview of the services performed in this report.*

Device Type	Service	Quantity
<b><i>Passed</i></b>		
Battery	Tested	4
Control Panel	Tested	2
Heat Detector	Visually Checked	21
Horn/Strobe	Tested	2
Monitoring	Tested	1
Pull Station	Tested	13
Smoke Detector	Tested	37
<b>Total</b>		<b>80</b>
<b>Grand Total</b>		<b>80</b>

# **Battery & Power Supply Testing**

*Generated by: BuildingReports.com*

Building: Tidewater - USARC 99th -  
Parkersburg WV046

Control Panel: 1 - Siemens  
FHD2009-U1

*The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.*

<b>Battery</b>								
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah	
<b>Passed</b>								
	1st FACP	75ah	12V					
	1st FACP	75ah	12V					
	1st FACP Garage Building	75ah	12V					
	1st FACP Garage Building	75ah	12V					

# Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Tidewater - USARC 99th -  
Parkersburg WV046

Control Panel: 1 - Siemens FHD2009-U1

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Type	Category	% of Inventory	Quantity
Battery	Control	5.00%	4
Control Panel	Control	2.50%	2
Heat Detector	Initiating	26.25%	21
Horn/Strobe	Indicating	2.50%	2
Monitoring	Monitor	1.25%	1
Pull Station	Initiating	16.25%	13
Smoke Detector	Initiating	46.25%	37

Type	Qty	Model #	Description	Install Date
------	-----	---------	-------------	--------------

## In Service - 1 Year to 2 Years

### Siemens

Battery	4			05/12/2022
Control Panel	1	FHD2009-U1		05/12/2022
Heat Detector	21	HI921		05/12/2022
Horn/Strobe	1			05/12/2022
Horn/Strobe	1	FHD2009-U1		05/12/2022
Monitoring	1	FHD2009-U1		05/12/2022
Pull Station	13	MSM-KD		05/12/2022
Smoke Detector	5	OOHC	Photoelectric	05/12/2022
Smoke Detector	32	OP921	Photoelectric	05/12/2022

Building: Tidewater - USARC 99th -  
Parkersburg WV046

Control Panel: 2 - Siemens FHD2009-U1

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Type	Qty	Model #	Description	Install Date
------	-----	---------	-------------	--------------

## In Service - 1 Year to 2 Years

### Siemens

Control Panel	1	FHD2009-U1		05/12/2022
---------------	---	------------	--	------------