

# Fire Suppression Inspection Certificate

*For*

Tidewater - USARC 99th -  
Parkersburg WV046  
4603 Camden Avenue  
Parkersburg, WV 26101

*This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.*

*Inspection Date*  
May 3, 2024

Building: Tidewater - USARC 99th - Parkersburg WV046  
Contact: Jennifer Bailie  
Title: Manager

Company: Brewer and Company  
Contact: Antwon Davis  
Title: Technician(Service & Inspections)

# Executive Summary

Generated by: BuildingReports.com

## Building Information

<b>Building:</b> Tidewater – USARC 99th – Parkersburg WV046	<b>Contact:</b> Jennifer Bailie
<b>Address:</b> 4603 Camden Avenue	<b>Phone:</b> 724.544.5252
<b>Address:</b>	<b>Fax:</b>
<b>City/State/ZIP Code:</b> Parkersburg, WV 26101	<b>Mobile:</b>
<b>Country:</b> United States of America	<b>Email:</b> jennifer.a.bailie.ctr@mail.mil

## Inspection Performed By

<b>Company:</b> Brewer and Company	<b>Inspector:</b> Antwon Davis
<b>Address:</b> 3601 7th Avenue	<b>Phone:</b> 304-744-5314
<b>Address:</b>	<b>Fax:</b>
<b>City/State/ZIP Code:</b> Charleston, WV 25387	<b>Mobile:</b> 304-549-9963
<b>Country:</b> United States of America	<b>Email:</b> antwon.davis@brewerfire.com

Inspection Summary								
Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Auxiliary	1	14.29%	1	100.00%	1	100.00%	0	0.00%
Container	2	28.57%	2	100.00%	2	100.00%	0	0.00%
Initiating	2	28.57%	2	100.00%	2	100.00%	0	0.00%
Notification	1	14.29%	1	100.00%	1	100.00%	0	0.00%
Pre-Engineered	1	14.29%	1	100.00%	1	100.00%	0	0.00%
<b>Totals</b>	<b>7</b>	<b>100%</b>	<b>7</b>	<b>100.00%</b>	<b>7</b>	<b>100.00%</b>	<b>0</b>	<b>0.00%</b>


## Certification

**Company:** Brewer and Company

**Building:** Tidewater – USARC 99th – Parkersburg WV046

**Inspector:** Antwon Davis

**Contact:** Jennifer Bailie



Signed: May 3, 2024

Signed: May 1, 2024

## Antwon Davis Certifications

Certification Type	Number
Getz Equipment Innovators Certification- NFPA 10 Portable Fire Extinguishers	
ICC/NAFED Pre-Engineered Kitchen Fire Extinguishing Systems Technician	
West Virginia License – Fire Extinguisher Technician	

# ***Inspection & Testing***

*Generated by: BuildingReports.com*

## **Building: Tidewater - USARC 99th - Parkersburg WV046**

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Fan Shutdown	kitchen fan and gas shut down	Tested	3:08:07 PM	05/03/2024
Cartridge	kitchen R101-20	Tested	3:07:56 PM	05/03/2024
Cylinder	kitchen 3 gal Ansul Tank	Tested	3:07:53 PM	05/03/2024
Fusible Link	kitchen	Tested	3:08:04 PM	05/03/2024
Pull Station	kitchen	Tested	3:07:59 PM	05/03/2024
Building Fire Alarm	kitchen report to FACP	Tested	3:08:10 PM	05/03/2024
Kitchen System	kitchen Ansul Control Head	Tested	3:07:49 PM	05/03/2024

# ***Auxiliary Functions Testing***

*Generated by: BuildingReports.com*

Building: Tidewater - USARC 99th -  
Parkersburg WV046

All Protected Areas

*The Auxiliary Functions Testing section list each of the ancillary items, systems and emergency equipment that are controlled by the system control unit. The items are listed by category, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b>Fan Shutdown</b>				
Exhaust	kitchen fan and gas shut down	Passed	82280314	<input type="checkbox"/>

# **Notification Report**

*Generated by: BuildingReports.com*

Building: Tidewater - USARC 99th - Parkersburg WV046	All Protected Areas			
<i>Message, signals, signage and communications for occupants of areas protected within this inspection.</i>				
Device Type	Type	Location	Comment	ScanID
Building Fire Alarm		kitchen report to FACP	Passed	82280315

# ***Time, Temperature & Level Testing***

*Generated by: BuildingReports.com*

Building: Tidewater - USARC 99th - Parkersburg WV046	All Protected Areas					
<i>The Time, Temperature, &amp; Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level.</i>						
Type	Location	Comment	Sec	Deg	Lvl	ScanID
<b>Fusible Link</b>						
ML	kitchen	Passed	n/a	360F	n/a	82280313

# Agent Container Report

Generated by: BuildingReports.com

Building: Tidewater - USARC 99th - Parkersburg WV046	All Protected Areas									
<i>A container of stored agent to be used in case of a fire emergency.</i>										
<b>Cartridge</b>										
<b>Location</b>	<b>Weight</b>	<b>Type</b>	<b>Size</b>	<b>Hydro Date</b>	<b>ScanID</b>					
kitchen R101-20	42 7/8 oz	Carbon Dioxide	101-20	03/22/2023	82280311					
<b>Cylinder</b>										
<b>Location</b>	<b>Manufacturer</b>	<b>Type</b>	<b>Supply</b>	<b>Size</b>	<b>ScanID</b>					
kitchen 3 gal Ansul Tank	Ansul	Wet Chemical	Slave	3 gal	82280310					
<b>Method</b>	<b>Weight</b>	<b>Pressure</b>	<b>UL 300</b>	<b>Total Flow Points Used</b>	<b>Serial Number</b>					
			<input type="checkbox"/>							
<b>Install Date</b>		<b>Recharged</b>		<b>Hydro</b>						
08/23/2023		03/22/2023		08/23/2023						

# Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Tidewater - USARC 99th -  
Parkersburg WV046

All Protected Areas

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Item	Category	% of Inventory	Quantity	
Building Fire Alarm	Notification	14.29%	1	
Cartridge	Container	14.29%	1	
Cylinder	Container	14.29%	1	
Fan Shutdown	Auxiliary	14.29%	1	
Fusible Link	Initiating	14.29%	1	
Kitchen System	Pre-Engineered	14.29%	1	
Pull Station	Initiating	14.29%	1	
Device or Item	Qty	Model #	Description	Install Date
<b><i>In Service - 90 Days - 1 Year</i></b>				
Cartridge	1	101-20	Carbon Dioxide	08/23/2023
Cylinder	1	R-102	Wet Chemical	08/23/2023
Fusible Link	1		ML	08/23/2023
<b><i>In Service - 1 Year to 2 Years</i></b>				
Kitchen System	1	R-102		03/22/2023
<b><i>In Service - 15 Years to 25 Years</i></b>				
Building Fire Alarm	1			03/22/2008
Fan Shutdown	1		Exhaust	03/22/2008
Pull Station	1		Cable	03/22/2008