



Tidewater - USARC 99th - Bridgeport WV010

Rt 2 Box 77
Meadowbrook Road
Bridgeport, WV 26330
304-544-5252

Building Contact: Jennifer Bailie
Title: Manager

Company: Brewer and Company
Contact: Hunter Mouse
Title: Alarm Tech

Semi-Annual Inspection **Inspection Date: Oct 1, 2024**

This Inspection was performed in accordance with applicable Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.



EXECUTIVE SUMMARY

Generated by: BuildingReports.com

Building Information

Tidewater - USARC 99th - Bridgeport WV010
Rt 2 Box 77
Meadowbrook Road
Bridgeport, WV 26330
United States of America

Contact: Jennifer Bailie

Phone: 724.544.5252

Fax:

Mobile:

Email: jennifer.a.bailie.ctr@mail.mil

Inspection Performed By

Brewer and Company
3601 7th Avenue
Meadowbrook Road
Charleston, WV 25387
United States of America

Inspector: Hunter Mouse

Phone: 681.867.8996

Fax:

Mobile:

Email: hunter.mouse@brewerfire.com

System Control Unit

| | | |
|-----------------------------------|---------------------------------|----------------------------|
| Manufacturer: Ansul | Discharge Time: | Predischarge Delay: |
| Model Number: R-102 | Install Date: 12/15/2020 | |
| Software Version: | Version Date: 12/15/2020 | |
| Location: Kitchen 64974421 | Current Protection: | |

Systems Inspected

| System Type | Protected Area | Devices |
|--------------------|-----------------------|----------------|
| Kitchen | Range Hood- | 6 |


Inspection Summary

| Category | Total Items | | Serviced | | Passed | | Failed/Other | |
|---------------|-------------|-------------|----------|----------------|----------|----------------|--------------|--------------|
| | Qty | % | Qty | % | Qty | % | Qty | % |
| Container | 3 | 50.00% | 3 | 100.00% | 3 | 100.00% | 0 | 0.00% |
| Controls | 1 | 16.67% | 1 | 100.00% | 1 | 100.00% | 0 | 0.00% |
| Initiating | 2 | 33.33% | 2 | 100.00% | 2 | 100.00% | 0 | 0.00% |
| Totals | 6 | 100% | 6 | 100.00% | 6 | 100.00% | 0 | 0.00% |

Certification

Company: Brewer and Company

Inspector: Hunter Mouse



Signed: Oct 1, 2024

Building: Tidewater - USARC 99th -

Bridgeport WV010

Contact: Jennifer Bailie



Signed: Oct 1, 2024

Hunter Mouse Certifications

| Certification Type | Number |
|--|----------------------|
| Getz Equipment Innovators Certification- NFPA 10 Portable Fire Extinguishers | |
| NFPA 80 (2016) Online Training Certification | Swing Door/Fire Door |
| OSHA 10-Hour Construction | |
| West Virginia Fire Protection Worker – Fire Extinguisher Technician | |
| West Virginia License - Low Voltage Electrician | |

INSPECTION & TESTING

Generated by: BuildingReports.com

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Building: Tidewater - USARC 99th - Bridgeport WV010

| Device Type | Location | Service | Time | Date |
|----------------------------|----------|---------|------------|------------|
| PASSED | | | | |
| Kitchen Range Hood- | | | | |
| CO2 Tank | Kitchen | Tested | 9:36:03 AM | 10/01/2024 |
| Control Panel | Kitchen | Tested | 9:35:55 AM | 10/01/2024 |
| Cylinder | Kitchen | Tested | 9:36:06 AM | 10/01/2024 |
| Fusible Link | Kitchen | Tested | 9:36:16 AM | 10/01/2024 |
| Nozzle | Kitchen | Tested | 9:36:12 AM | 10/01/2024 |
| Pull Station | Kitchen | Tested | 9:35:52 AM | 10/01/2024 |

TIME, TEMPERATURE & LEVEL TESTING

Generated by: BuildingReports.com

The Time, Temperature, & Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level. Items are grouped by Passed or Failed/Other.

Building: Tidewater - USARC 99th - Bridgeport
WV010

All Protected Areas

| Type | Location | Comment | Sec | Deg | Lvl | ScanID |
|---------------------|----------|---------|-----|------|-----|----------|
| PASSED | | | | | | |
| Fusible Link | | | | | | |
| K | Kitchen | Passed | n/a | 360F | n/a | 64974425 |

AGENT CONTAINER REPORT

Generated by: BuildingReports.com

A container of stored agent to be used in case of a fire emergency.

Building: Tidewater - USARC 99th - Bridgeport
WV010

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank

| Location | | Manufacturer | | Model # | | Type | | Serial # | | ScanID |
|------------|----------|--------------|---------------|-------------------|--------------------------|---------------|--|-------------|--|--------------------------|
| Kitchen | | Ansul | | 101-20 part 17492 | | High Pressure | | | | 64974422 |
| Hydro Date | Capacity | Gross Weight | Actual Weight | Tare Weight | Lvl. Indicator | Liquid Level | | Puff Tested | | |
| 02/18/2021 | | | | | <input type="checkbox"/> | | | | | <input type="checkbox"/> |

Cylinder

| Location | | Manufacturer | | Model # | | Type | | ScanID | |
|----------------------|--|-------------------------------------|--|------------|--|------------------------|--|------------|--|
| Kitchen | | Ansul | | | | Wet Chemical | | 64974423 | |
| Supply | | Size | | Weight | | Total Flow Points Used | | Pressure | |
| Master | | 3 gal | | | | | | | |
| Method | | UL 300? | | Mfg. Date | | Recharged Date | | Hydro Date | |
| Mechanical-Automatic | | <input checked="" type="checkbox"/> | | 02/18/2021 | | 02/18/2021 | | 02/18/2021 | |

Nozzle

| Location | | Manufacturer | | Model # | | Qty | Install Date | ScanID |
|----------|--|--------------|--|---------|--|-----|--------------|----------|
| Kitchen | | Ansul | | | | 6 | 12/15/2008 | 64974424 |

KITCHEN SYSTEM

Generated by: BuildingReports.com

A pre-engineered wet chemical fire-extinguishing system that discharges wet chemical from fixed nozzles and piping by means of expellant gas or a dry chemical fire-extinguishing system that discharges dry chemical from fixed nozzles or hand hose lines by means of expellant gas.

Building: Tidewater - USARC 99th - Bridgeport
WV010

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank

| Location | Manufacturer | Model # | Type | Serial # | ScanID | | |
|------------|--------------|-------------------|---------------|-------------|--------------------------|--------------|--------------------------|
| Kitchen | Ansul | 101-20 part 17492 | High Pressure | | 64974422 | | |
| Hydro Date | Capacity | Gross Weight | Actual Weight | Tare Weight | Lvl. Indicator | Liquid Level | Puff Tested |
| 02/18/2021 | | | | | <input type="checkbox"/> | | <input type="checkbox"/> |

Control Panel

| Location | Manufacturer | Model # | Serial # | ScanID |
|--------------------|----------------|-----------------|------------------|---------------|
| Kitchen | Ansul | R-102 | S240084 | 64974421 |
| Predischarge Delay | Discharge Time | Protection Type | Software Version | Software Date |
| | | | | 12/15/2020 |

Cylinder

| Location | Manufacturer | Model # | Type | ScanID |
|----------------------|-------------------------------------|------------|------------------------|------------|
| Kitchen | Ansul | | Wet Chemical | 64974423 |
| Supply | Size | Weight | Total Flow Points Used | Pressure |
| Master | 3 gal | | | |
| Method | UL 300? | Mfg. Date | Recharged Date | Hydro Date |
| Mechanical-Automatic | <input checked="" type="checkbox"/> | 02/18/2021 | 02/18/2021 | 02/18/2021 |

Fusible Link

KITCHEN RANGE HOOD- (continued)

| Temp | Location | Quantity | Type | Manufacturer | Model # | ScanID |
|---------------------|--------------|--------------|---------|--------------|--------------|----------|
| 360F | Kitchen | 3 | K | Ansul | | 64974425 |
| Nozzle | | | | | | |
| Location | | Manufacturer | Model # | Qty | Install Date | ScanID |
| Kitchen | | Ansul | | 6 | 12/15/2008 | 64974424 |
| Pull Station | | | | | | |
| Location | Manufacturer | Model # | Type | Cover | Serial # | ScanID |
| Kitchen | Ansul | | Cable | No Cover | | 64974420 |

INVENTORY & WARRANTY REPORT

Generated by: BuildingReports.com

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Building: Tidewater - USARC 99th - Bridgeport WV010

| Device or Type | Category | % of Inventory | Quantity |
|----------------|------------|----------------|----------|
| CO2 Tank | Container | 16.67% | 1 |
| Control Panel | Controls | 16.67% | 1 |
| Cylinder | Container | 16.67% | 1 |
| Fusible Link | Initiating | 16.67% | 1 |
| Nozzle | Container | 16.67% | 1 |
| Pull Station | Initiating | 16.67% | 1 |

| Type | Qty | Model # | Description | Install Date |
|----------------------------|-----|---------|-------------|--------------|
| NEW (UNDER 90 DAYS) | | | | |

Kitchen Range Hood-

| | | | | |
|--------------|---|--|---|------------|
| Fusible Link | 1 | | K | 10/01/2024 |
|--------------|---|--|---|------------|

IN SERVICE - 3 YEARS TO 5 YEARS

Kitchen Range Hood-

| | | | | |
|---------------|---|-------------------|---------------|------------|
| CO2 Tank | 1 | 101-20 part 17492 | High Pressure | 02/18/2021 |
| Control Panel | 1 | R-102 | | 12/15/2020 |
| Cylinder | 1 | | Wet Chemical | 02/18/2021 |
| Pull Station | 1 | | Cable | 12/15/2020 |

IN SERVICE - 15 YEARS TO 25 YEARS

Kitchen Range Hood-

| | | | | |
|--------|---|--|--|------------|
| Nozzle | 1 | | | 12/15/2008 |
|--------|---|--|--|------------|