



Tidewater - USARC 99th - Grafton WV014

363 Luby Street
Grafaton, WV 26354
724-544-5252

Building Contact: Jennifer Bailie
Title: Manager

Company: Brewer and Company
Contact: Hunter Mouse
Title: Alarm Tech

Semi-Annual Inspection **Inspection Date: Oct 1, 2024**

This Inspection was performed in accordance with applicable Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.



EXECUTIVE SUMMARY

Generated by: BuildingReports.com

Building Information

Tidewater - USARC 99th - Grafton WV014 363 Luby Street Grafaton, WV 26354 United States of America	Contact: Jennifer Bailie Phone: 724-544-5252 Fax: Mobile: Email: jennifer.a.bailie.ctr@mail.mil
------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------

Inspection Performed By

Brewer and Company 3601 7th Avenue Charleston, WV 25387 United States of America	Inspector: Hunter Mouse Phone: 681.867.8996 Fax: Mobile: Email: hunter.mouse@brewerfire.com
--------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------

Systems Inspected

System Type	Protected Area	Devices
Kitchen	Range Hood-	6

Inspection Summary

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Container	3	50.00%	3	100.00%	3	100.00%	0	0.00%
Initiating	2	33.33%	2	100.00%	2	100.00%	0	0.00%
Pre-Engineered	1	16.67%	1	100.00%	1	100.00%	0	0.00%
Totals	6	100%	6	100.00%	6	100.00%	0	0.00%

Certification

Company: Brewer and Company
Inspector: Hunter Mouse

Building: Tidewater - USARC 99th - Grafton
WV014
Contact: Jennifer Bailie



Signed: Oct 1, 2024

Hunter Mouse Certifications

Certification Type	Number
Getz Equipment Innovators Certification- NFPA 10 Portable Fire Extinguishers	
NFPA 80 (2016) Online Training Certification	Swing Door/Fire Door
OSHA 10-Hour Construction	
West Virginia Fire Protection Worker – Fire Extinguisher Technician	
West Virginia License - Low Voltage Electrician	

INSPECTION & TESTING

Generated by: BuildingReports.com

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Building: Tidewater - USARC 99th - Grafton WV014

Device Type	Location	Service	Time	Date
PASSED				
Kitchen Range Hood-				
CO2 Tank	1st Kitchen	Tested	10:54:23 AM	10/01/2024
Cylinder	1st Kitchen	Tested	10:54:12 AM	10/01/2024
Fusible Link	1st Kitchen	Tested	10:54:39 AM	10/01/2024
Kitchen System	1st Kitchen	Tested	10:54:08 AM	10/01/2024
Nozzle	1st Kitchen	Tested	10:54:33 AM	10/01/2024
Pull Station	1st Kitchen	Tested	10:54:29 AM	10/01/2024

TIME, TEMPERATURE & LEVEL TESTING

Generated by: BuildingReports.com

The Time, Temperature, & Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level. Items are grouped by Passed or Failed/Other.

Building: Tidewater - USARC 99th - Grafton WV014

All Protected Areas

Type	Location	Comment	Sec	Deg	Lvl	ScanID
PASSED						
Fusible Link						
K	1st Kitchen	Passed	n/a	360F	n/a	64974415

AGENT CONTAINER REPORT

Generated by: BuildingReports.com

A container of stored agent to be used in case of a fire emergency.

Building: Tidewater - USARC 99th - Grafton WV014

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank							
Location		Manufacturer		Model #	Type	Serial #	ScanID
1st Kitchen		Ansul		101-20 part 17492	High Pressure	64974412	

Hydro Date	Capacity	Gross Weight	Actual Weight	Tare Weight	Lvl. Indicator	Liquid Level	Puff Tested
02/04/2020					□		□

Cylinder							
Location		Manufacturer		Model #		Type	
1st Kitchen		Ansul		R-102		Wet Chemical	
Supply		Size		Weight		Total Flow Points Used	
Master		3 gal					
Method		UL 300?		Mfg. Date		Recharged Date	
Mechanical-Manual		<input checked="" type="checkbox"/>		02/04/2020		02/04/2021	
Hydro Date							
02/04/2020							

Nozzle					
Location		Manufacturer		Model #	ScanID
1st Kitchen		Ansul		6	11/24/2008
					64974414

KITCHEN SYSTEM

Generated by: BuildingReports.com

A pre-engineered wet chemical fire-extinguishing system that discharges wet chemical from fixed nozzles and piping by means of expellant gas or a dry chemical fire-extinguishing system that discharges dry chemical from fixed nozzles or hand hose lines by means of expellant gas.

Building: Tidewater - USARC 99th - Grafton WV014

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank

Location	Manufacturer	Model #	Type	Serial #	ScanID		
1st Kitchen	Ansul	101-20 part 17492	High Pressure		64974412		
Hydro Date	Capacity	Gross Weight	Actual Weight	Tare Weight	Lvl. Indicator	Liquid Level	Puff Tested
02/04/2020					<input type="checkbox"/>		<input type="checkbox"/>

Cylinder

Location	Manufacturer	Model #	Type	ScanID
1st Kitchen	Ansul	R-102	Wet Chemical	64974411
Supply	Size	Weight	Total Flow Points Used	Pressure
Master	3 gal			
Method	UL 300?	Mfg. Date	Recharged Date	Hydro Date
Mechanical-Manual	<input checked="" type="checkbox"/>	02/04/2020	02/04/2021	02/04/2020

Fusible Link

Temp	Location	Quantity	Type	Manufacturer	Model #	ScanID
360F	1st Kitchen	2	K	Ansul		64974415

Kitchen System

Location	Manufacturer	Model #	Type	ScanID		
1st Kitchen	Ansul			64974410		
Hydro Date	PSI	Links	Qty	Flows Available	Flows Used	UL300?

KITCHEN RANGE HOOD- (continued)

Hydro Date (continued)	Links	Qty	Flows Available	Flows Used	UL300?
02/04/2021	360				<input type="checkbox"/>
Nozzle					
Location	Manufacturer	Model #	Qty	Install Date	ScanID
1st Kitchen	Ansul		6	11/24/2008	64974414
Pull Station					
Location	Manufacturer	Model #	Type	Cover	Serial #
1st Kitchen	Ansul		Single Action	No Cover	64974413

INVENTORY & WARRANTY REPORT

Generated by: BuildingReports.com

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Building: Tidewater - USARC 99th - Grafton WV014

Device or Type	Category	% of Inventory	Quantity
CO2 Tank	Container	16.67%	1
Cylinder	Container	16.67%	1
Fusible Link	Initiating	16.67%	1
Kitchen System	Pre-Engineered	16.67%	1
Nozzle	Container	16.67%	1
Pull Station	Initiating	16.67%	1

Type	Qty	Model #	Description	Install Date
NEW (UNDER 90 DAYS)				

Kitchen Range Hood-

Fusible Link	1		K	10/01/2024
--------------	---	--	---	------------

IN SERVICE - 3 YEARS TO 5 YEARS

Kitchen Range Hood-

CO2 Tank	1	101-20 part 17492	High Pressure	02/04/2021
Cylinder	1	R-102	Wet Chemical	02/04/2021

IN SERVICE - 15 YEARS TO 25 YEARS

Kitchen Range Hood-

Kitchen System	1			11/24/2008
Nozzle	1			11/24/2008
Pull Station	1		Single Action	11/24/2008