



Tidewater - USARC 99th - Kingwood WV022

504 N Preston Highway
Kingwood, WV 26537
724-544-5252


Building Contact: Jennifer Bailie
Title: Manager

Company: Brewer and Company
Contact: Hunter Mouse
Title: Alarm Tech

Semi-Annual Inspection

Inspection Date: Oct 15, 2024

This Inspection was performed in accordance with applicable Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.



EXECUTIVE SUMMARY

Generated by: BuildingReports.com

Building Information

Tidewater - USARC 99th - Kingwood WV022 504 N Preston Highway Kingwood, WV 26537 United States of America	Contact: Jennifer Bailie
	Phone: 724-544-5252
	Fax:
	Mobile:
	Email: jennifer.a.bailie.ctr@mail.mil

Inspection Performed By

Brewer and Company 3601 7th Avenue Charleston, WV 25387 United States of America	Inspector: Hunter Mouse
	Phone: 681.867.8996
	Fax:
	Mobile:
	Email: hunter.mouse@brewerfire.com

Systems Inspected

System Type	Protected Area	Devices
Kitchen	Range Hood-	6


Inspection Summary

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Container	3	50.00%	3	100.00%	3	100.00%	0	0.00%
Initiating	2	33.33%	2	100.00%	2	100.00%	0	0.00%
Pre-Engineered	1	16.67%	1	100.00%	1	100.00%	0	0.00%
Totals	6	100%	6	100.00%	6	100.00%	0	0.00%


Certification

Company: Brewer and Company
Inspector: Hunter Mouse

Building: Tidewater - USARC 99th -
Kingwood WV022
Contact: Jennifer Bailie



Signed: Oct 15, 2024



Signed: Oct 15, 2024

Hunter Mouse Certifications

Certification Type	Number
Getz Equipment Innovators Certification- NFPA 10 Portable Fire Extinguishers	
NFPA 80 (2016) Online Training Certification	Swing Door/Fire Door
OSHA 10-Hour Construction	
West Virginia Fire Protection Worker – Fire Extinguisher Technician	
West Virginia License - Low Voltage Electrician	

INSPECTION & TESTING

Generated by: BuildingReports.com

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other . Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Building: Tidewater - USARC 99th - Kingwood WV022

Device Type	Location	Service	Time	Date
PASSED				
Kitchen Range Hood-				
CO2 Tank	1st Kitchen	Tested	11:39:28 AM	10/15/2024
Cylinder	1st Kitchen	Tested	11:39:25 AM	10/15/2024
Fusible Link	1st Kitchen	Tested	11:39:36 AM	10/15/2024
Kitchen System	1st Kitchen	Tested	11:39:20 AM	10/15/2024
Nozzle	1st Kitchen	Tested	11:39:34 AM	10/15/2024
Pull Station	1st Kitchen	Tested	11:39:31 AM	10/15/2024

TIME, TEMPERATURE & LEVEL TESTING

Generated by: BuildingReports.com

The Time, Temperature, & Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level. Items are grouped by Passed or Failed/Other.

Building: Tidewater - USARC 99th - Kingwood
WV022

All Protected Areas

Type	Location	Comment	Sec	Deg	Lvl	ScanID
PASSED						
Fusible Link						
K	1st Kitchen	Passed	n/a	360F	n/a	64974419

AGENT CONTAINER REPORT

Generated by: BuildingReports.com

A container of stored agent to be used in case of a fire emergency.

Building: Tidewater - USARC 99th - Kingwood
WV022

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank

Location		Manufacturer		Model #	Type		Serial #		ScanID	
1st Kitchen		Ansul		101-20 part 17492	High Pressure				64974416	
Hydro Date	Capacity	Gross Weight	Actual Weight	Tare Weight	Lvl. Indicator	Liquid Level	Puff Tested			
02/23/2020					<input type="checkbox"/>		<input type="checkbox"/>			

Cylinder

Location		Manufacturer	Model #	Type	ScanID
1st Kitchen		Ansul	R-102	Wet Chemical	64974415
Supply		Size	Weight	Total Flow Points Used	Pressure
Master		3 gal			
Method		UL 300?	Mfg. Date	Recharged Date	Hydro Date
Mechanical-Manual		<input type="checkbox"/>	02/23/2020	02/23/2021	02/23/2020

Nozzle

Location		Manufacturer	Model #	Qty	Install Date	ScanID
1st Kitchen		Ansul		6	11/24/2008	64974418

KITCHEN SYSTEM

Generated by: BuildingReports.com

A pre-engineered wet chemical fire-extinguishing system that discharges wet chemical from fixed nozzles and piping by means of expellant gas or a dry chemical fire-extinguishing system that discharges dry chemical from fixed nozzles or hand hose lines by means of expellant gas.

Building: Tidewater - USARC 99th - Kingwood
WV022

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank

Location	Manufacturer	Model #	Type	Serial #	ScanID
1st Kitchen	Ansul	101-20 part 17492	High Pressure		64974416

Hydro Date	Capacity	Gross Weight	Actual Weight	Tare Weight	Lvl. Indicator	Liquid Level	Puff Tested
02/23/2020					<input type="checkbox"/>		<input type="checkbox"/>

Cylinder

Location	Manufacturer	Model #	Type	ScanID
1st Kitchen	Ansul	R-102	Wet Chemical	64974415

Supply	Size	Weight	Total Flow Points Used	Pressure
Master	3 gal			

Method	UL 300?	Mfg. Date	Recharged Date	Hydro Date
Mechanical-Manual	<input type="checkbox"/>	02/23/2020	02/23/2021	02/23/2020

Fusible Link

Temp	Location	Quantity	Type	Manufacturer	Model #	ScanID
360F	1st Kitchen	3	K	Ansul		64974419

Kitchen System

Location	Manufacturer	Model #	Type	ScanID
1st Kitchen	Ansul	R-102		64974414

KITCHEN RANGE HOOD- (continued)

Hydro Date	PSI	Links	Qty	Flows Available	Flows Used	UL300?
05/01/2020		360F				<input checked="" type="checkbox"/>

Nozzle

Location	Manufacturer	Model #	Qty	Install Date	ScanID
1st Kitchen	Ansul		6	11/24/2008	64974418

Pull Station

Location	Manufacturer	Model #	Type	Cover	Serial #	ScanID
1st Kitchen	Ansul		Single Action	No Cover		64974417

INVENTORY & WARRANTY REPORT

Generated by: BuildingReports.com

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Building: Tidewater - USARC 99th - Kingwood WV022

Device or Type	Category	% of Inventory	Quantity
CO2 Tank	Container	16.67%	1
Cylinder	Container	16.67%	1
Fusible Link	Initiating	16.67%	1
Kitchen System	Pre-Engineered	16.67%	1
Nozzle	Container	16.67%	1
Pull Station	Initiating	16.67%	1

Type	Qty	Model #	Description	Install Date
------	-----	---------	-------------	--------------

IN SERVICE - 3 YEARS TO 5 YEARS

Kitchen Range Hood-

CO2 Tank	1	101-20 part 17492	High Pressure	02/23/2020
Cylinder	1	R-102	Wet Chemical	02/23/2020
Fusible Link	1		K	05/01/2020
Kitchen System	1	R-102		05/01/2020

IN SERVICE - 15 YEARS TO 25 YEARS

Kitchen Range Hood-

Nozzle	1			11/24/2008
Pull Station	1		Single Action	11/24/2008