



Tidewater - USARC 99th - Morgantown WV029

228 Comfort Inn Road
Morgantown, WV 26354
724-544-5252

Building Contact: Jennifer Bailie

Title: Manager

Company: Brewer and Company

Contact: Hunter Mouse

Title: Alarm Tech

Semi-Annual Inspection

Inspection Date: Nov 22, 2024

This Inspection was performed in accordance with applicable Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.



EXECUTIVE SUMMARY

Generated by: BuildingReports.com

Building Information

**Tidewater - USARC 99th -
Morgantown WV029**
228 Comfort Inn Road
Morgantown, WV 26354
United States of America

Contact: Jennifer Bailie

Phone: 724-544-5252

Fax:

Mobile:

Email: jennifer.a.bailie.ctr@mail.mil

Inspection Performed By

Brewer and Company
3601 7th Avenue
Charleston, WV 25387
United States of America

Inspector: Hunter Mouse

Phone: 681.867.8996

Fax:

Mobile:

Email: hunter.mouse@brewerfire.com

System Control Unit

Manufacturer: Ansul	Discharge Time:	Predischarge Delay:
Model Number: R-102	Install Date: 12/23/2020	
Software Version:	Version Date: 12/23/2020	
Location: Basement Kitchen 64974427	Current Protection:	

Systems Inspected

System Type	Protected Area	Devices
Kitchen	Range Hood-	6

Inspection Summary

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Container	3	50.00%	3	100.00%	3	100.00%	0	0.00%
Controls	1	16.67%	1	100.00%	1	100.00%	0	0.00%
Initiating	2	33.33%	2	100.00%	2	100.00%	0	0.00%
Totals	6	100%	6	100.00%	6	100.00%	0	0.00%

Certification

Company: Brewer and Company

Inspector: Hunter Mouse




Signed: Nov 22, 2024

Building: Tidewater - USARC 99th -

Morgantown WV029

Contact: Jennifer Bailie



Signed: Nov 22, 2024

Hunter Mouse Certifications

Certification Type	Number
Getz Equipment Innovators Certification- NFPA 10 Portable Fire Extinguishers	
NFPA 80 (2016) Online Training Certification	Swing Door/Fire Door
OSHA 10-Hour Construction	
West Virginia Fire Protection Worker – Fire Extinguisher Technician	
West Virginia License - Low Voltage Electrician	

INSPECTION & TESTING

Generated by: BuildingReports.com

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other . Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Building: Tidewater - USARC 99th - Morgantown WV029

Device Type	Location	Service	Time	Date
PASSED				
Kitchen Range Hood-				
CO2 Tank	Basement Kitchen	Tested	9:01:53 AM	11/22/2024
Control Panel	Basement Kitchen	Tested	9:01:47 AM	11/22/2024
Cylinder	Basement Kitchen	Tested	9:01:50 AM	11/22/2024
Fusible Link	Basement Kitchen	Tested	9:01:56 AM	11/22/2024
Nozzle	Basement Kitchen	Tested	9:02:00 AM	11/22/2024
Pull Station	Basement Kitchen	Tested	9:01:42 AM	11/22/2024

TIME, TEMPERATURE & LEVEL TESTING

Generated by: BuildingReports.com

The Time, Temperature, & Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level. Items are grouped by Passed or Failed/Other.

Building: Tidewater - USARC 99th - Morgantown
WV029

All Protected Areas

Type	Location	Comment	Sec	Deg	Lvl	ScanID
PASSED						
Fusible Link						
K	Basement Kitchen	Passed	n/a	360F	n/a	64974430

AGENT CONTAINER REPORT

Generated by: BuildingReports.com

A container of stored agent to be used in case of a fire emergency.

Building: Tidewater - USARC 99th - Morgantown
WV029

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank

Location		Manufacturer		Model #		Type		Serial #		ScanID
Basement Kitchen		Ansul		101-20 part#17492		High Pressure				64974429
Hydro Date	Capacity	Gross Weight	Actual Weight	Tare Weight	Lvl. Indicator	Liquid Level	Puff Tested			
02/04/2021					<input type="checkbox"/>			<input type="checkbox"/>		

Cylinder

Location		Manufacturer		Model #		Type		ScanID		
Basement Kitchen		Ansul		R-102		Wet Chemical		64974428		
Supply		Size		Weight		Total Flow Points Used		Pressure		
Master		6 gal								
Method		UL 300?		Mfg. Date		Recharged Date		Hydro Date		
		<input type="checkbox"/>		02/04/2021		02/04/2021		02/04/2021		

Nozzle

Location		Manufacturer		Model #		Qty	Install Date	ScanID
Basement Kitchen		Ansul				5	12/23/2008	64974431

KITCHEN SYSTEM

Generated by: BuildingReports.com

A pre-engineered wet chemical fire-extinguishing system that discharges wet chemical from fixed nozzles and piping by means of expellant gas or a dry chemical fire-extinguishing system that discharges dry chemical from fixed nozzles or hand hose lines by means of expellant gas.

Building: Tidewater - USARC 99th - Morgantown
WV029

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank

Location	Manufacturer	Model #	Type	Serial #	ScanID		
Basement Kitchen	Ansul	101-20 part#17492	High Pressure		64974429		
Hydro Date	Capacity	Gross Weight	Actual Weight	Tare Weight	Lvl. Indicator	Liquid Level	Puff Tested
02/04/2021					<input type="checkbox"/>		<input type="checkbox"/>

Control Panel

Location	Manufacturer	Model #	Serial #	ScanID
Basement Kitchen	Ansul	R-102		64974427
Predischarge Delay	Discharge Time	Protection Type	Software Version	Software Date
				12/23/2020

Cylinder

Location	Manufacturer	Model #	Type	ScanID
Basement Kitchen	Ansul	R-102	Wet Chemical	64974428
Supply	Size	Weight	Total Flow Points Used	Pressure
Master	6 gal			
Method	UL 300?	Mfg. Date	Recharged Date	Hydro Date
	<input type="checkbox"/>	02/04/2021	02/04/2021	02/04/2021

Fusible Link

Temp	Location	Quantity	Type	Manufacturer	Model #	ScanID

KITCHEN RANGE HOOD- (continued)

Fusible Link (continued)

Temp (continued)	Location	Quantity	Type	Manufacturer	Model #	ScanID
360F	Basement Kitchen	3	K	Ansul		64974430

Nozzle

Location	Manufacturer	Model #	Qty	Install Date	ScanID
Basement Kitchen	Ansul		5	12/23/2008	64974431

Pull Station

Location	Manufacturer	Model #	Type	Cover	Serial #	ScanID
Basement Kitchen	Ansul		Single Action			64974426

INVENTORY & WARRANTY REPORT

Generated by: BuildingReports.com

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Building: Tidewater - USARC 99th - Morgantown WV029

Device or Type	Category	% of Inventory	Quantity
CO2 Tank	Container	16.67%	1
Control Panel	Controls	16.67%	1
Cylinder	Container	16.67%	1
Fusible Link	Initiating	16.67%	1
Nozzle	Container	16.67%	1
Pull Station	Initiating	16.67%	1

Type	Qty	Model #	Description	Install Date
IN SERVICE - 3 YEARS TO 5 YEARS				

Kitchen Range Hood-

CO2 Tank	1	101-20 part#17492	High Pressure	02/04/2021
Control Panel	1	R-102		12/23/2020
Cylinder	1	R-102	Wet Chemical	02/04/2021
Pull Station	1		Single Action	12/23/2020

IN SERVICE - 15 YEARS TO 25 YEARS

Kitchen Range Hood-

Fusible Link	1		K	12/23/2008
Nozzle	1			12/23/2008