



Tidewater - USARC 99th - Bridgeport WV010

Rt 2 Box 77
Meadowbrook Road
Bridgeport, WV 26330
304-544-5252

Building Contact: Jennifer Bailie
Title: Manager

Company: Brewer and Company
Contact: Garrett Watson
Title: Fire Alarm Tech

Inspection Date: Apr 25, 2025

This Inspection was performed in accordance with applicable Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.



EXECUTIVE SUMMARY

Generated by: BuildingReports.com

Building Information

Tidewater - USARC 99th - Bridgeport WV010
Rt 2 Box 77
Meadowbrook Road
Bridgeport, WV 26330
United States of America

Contact: Jennifer Bailie
Phone: 724.544.5252
Fax:
Mobile:
Email: jennifer.a.bailie.ctr@mail.mil

Inspection Performed By

Brewer and Company
3601 7th Avenue
Charleston, WV 25387
United States of America

Inspector: Garrett Watson
Phone: 304.382.8814
Fax:
Mobile:
Email: garrett.watson@brewerfire.com

System Control Unit

Manufacturer: Ansul	Discharge Time:	Predischarge Delay:
Model Number: R-102	Install Date: 12/15/2020	
Software Version:	Version Date: 12/15/2020	
Location: Kitchen 64974421	Current Protection:	

Systems Inspected

System Type	Protected Area	Devices
Kitchen	Range Hood-	6

Inspection Summary

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Container	3	50.00%	3	100.00%	3	100.00%	0	0.00%
Controls	1	16.67%	1	100.00%	1	100.00%	0	0.00%
Initiating	2	33.33%	2	100.00%	2	100.00%	0	0.00%
Totals	6	100%	6	100.00%	6	100.00%	0	0.00%

Certification

Company: Brewer and Company

Inspector: Garrett Watson




Signed: Apr 25, 2025

Building: Tidewater - USARC 99th -

Bridgeport WV010

Contact: Jennifer Bailie



Signed: Apr 25, 2025

Garrett Watson Certifications

Certification Type	Number
Getz Equipment Innovators Certification- NFPA 10 Portable Fire Extinguishers	
ICC/NAFED Pre-Engineered Kitchen Fire Extinguishing Systems Technician	
NFPA 80 (2016) Online Training Certification	
OSHA 10-Hour Construction	
West Virginia Fire Protection Worker – Fire Extinguisher Technician	

INSPECTION & TESTING

Generated by: BuildingReports.com

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other . Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Building: Tidewater - USARC 99th - Bridgeport WV010

Device Type	Location	Service	Time	Date
PASSED				
Kitchen Range Hood-				
CO2 Tank	Kitchen	Tested	10:09:10 AM	04/25/2025
Control Panel	Kitchen	Tested	10:09:07 AM	04/25/2025
Cylinder	Kitchen	Tested	10:09:14 AM	04/25/2025
Fusible Link	Kitchen	Tested	10:09:21 AM	04/25/2025
Nozzle	Kitchen	Tested	10:09:18 AM	04/25/2025
Pull Station	Kitchen	Tested	10:09:04 AM	04/25/2025

TIME, TEMPERATURE & LEVEL TESTING

Generated by: BuildingReports.com

The Time, Temperature, & Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level. Items are grouped by Passed or Failed/Other.

Building: Tidewater - USARC 99th - Bridgeport
WV010

All Protected Areas

Type	Location	Comment	Sec	Deg	Lvl	ScanID
PASSED						
Fusible Link						
K	Kitchen	Passed	n/a	360F	n/a	64974425

AGENT CONTAINER REPORT

Generated by: BuildingReports.com

A container of stored agent to be used in case of a fire emergency.

Building: Tidewater - USARC 99th - Bridgeport
WV010

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank

Location	Manufacturer	Model #	Type	Serial #	ScanID		
Kitchen	Ansul	101-20 part 17492	High Pressure		64974422		
Hydro Date	Capacity	Gross Weight	Actual Weight	Tare Weight	Lvl. Indicator	Liquid Level	Puff Tested
02/18/2021					<input type="checkbox"/>		<input type="checkbox"/>

Cylinder

Location	Manufacturer	Model #	Type	ScanID
Kitchen	Ansul		Wet Chemical	64974423
Supply	Size	Weight	Total Flow Points Used	Pressure
Master	3 gal			
Method	UL 300?	Mfg. Date	Recharged Date	Hydro Date
Mechanical-Automatic	<input type="checkbox"/>	02/18/2021	02/18/2021	02/18/2021

Nozzle

Location	Manufacturer	Model #	Qty	Install Date	ScanID
Kitchen	Ansul		6	12/15/2008	64974424

KITCHEN SYSTEM

Generated by: BuildingReports.com

A pre-engineered wet chemical fire-extinguishing system that discharges wet chemical from fixed nozzles and piping by means of expellant gas or a dry chemical fire-extinguishing system that discharges dry chemical from fixed nozzles or hand hose lines by means of expellant gas.

Building: Tidewater - USARC 99th - Bridgeport
WV010

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank							
Location		Manufacturer		Model #		Type	
Kitchen		Ansul		101-20 part 17492		High Pressure	
Hydro Date	Capacity	Gross Weight	Actual Weight	Tare Weight	Lvl. Indicator	Liquid Level	Puff Tested
02/18/2021					<input type="checkbox"/>		<input type="checkbox"/>

Control Panel					
Location		Manufacturer		Model #	
Kitchen		Ansul		R-102	
Predischarge Delay		Discharge Time		Protection Type	
				Software Version	
				Software Date	
				12/15/2020	

Cylinder					
Location		Manufacturer		Model #	
Kitchen		Ansul		Wet Chemical	
Supply		Size		Total Flow Points Used	
Master		3 gal			
Method		UL 300?		Mfg. Date	
Mechanical-Automatic		<input type="checkbox"/>		02/18/2021	
				02/18/2021	
				02/18/2021	

Fusible Link						
Temp	Location	Quantity	Type	Manufacturer	Model #	ScanID

KITCHEN RANGE HOOD- (continued)

Fusible Link (continued)

Temp (continued)	Location	Quantity	Type	Manufacturer	Model #	ScanID
360F	Kitchen	3	K	Ansul		64974425

Nozzle

Location	Manufacturer	Model #	Qty	Install Date	ScanID
Kitchen	Ansul		6	12/15/2008	64974424

Pull Station

Location	Manufacturer	Model #	Type	Cover	Serial #	ScanID
Kitchen	Ansul		Cable	No Cover		64974420

INVENTORY & WARRANTY REPORT

Generated by: BuildingReports.com

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Building: Tidewater - USARC 99th - Bridgeport WV010

Device or Type	Category	% of Inventory	Quantity
CO2 Tank	Container	16.67%	1
Control Panel	Controls	16.67%	1
Cylinder	Container	16.67%	1
Fusible Link	Initiating	16.67%	1
Nozzle	Container	16.67%	1
Pull Station	Initiating	16.67%	1

Type	Qty	Model #	Description	Install Date
IN SERVICE - 90 DAYS - 1 YEAR				

Kitchen Range Hood-

Fusible Link	1		K	10/01/2024
--------------	---	--	---	------------

IN SERVICE - 3 YEARS TO 5 YEARS

Kitchen Range Hood-

CO2 Tank	1	101-20 part 17492	High Pressure	02/18/2021
Control Panel	1	R-102		12/15/2020
Cylinder	1		Wet Chemical	02/18/2021
Pull Station	1		Cable	12/15/2020

IN SERVICE - 15 YEARS TO 25 YEARS

Kitchen Range Hood-

Nozzle	1			12/15/2008
--------	---	--	--	------------