



Tidewater - USARC 99th - Bridgeport WV010

Rt 2 Box 77
Meadowbrook Road
Bridgeport, WV 26330
304-544-5252


Building Contact: Jennifer Bailie
Title: Manager

Company: Brewer and Company
Contact: Hunter Mouse
Title: Alarm Tech

Quarterly Inspection

Inspection Date: Sep 23, 2025

This Inspection was performed in accordance with applicable Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.



EXECUTIVE SUMMARY

Generated by: BuildingReports.com

Building Information

Tidewater - USARC 99th - Bridgeport WV010 Rt 2 Box 77 Meadowbrook Road Bridgeport, WV 26330 United States of America	Contact: Jennifer Bailie
	Phone: 724.544.5252
	Fax:
	Mobile:
	Email: jennifer.a.bailie.ctr@mail.mil

Inspection Performed By

Brewer and Company 3601 7th Avenue Charleston, WV 25387 United States of America	Inspector: Hunter Mouse
	Phone: 681.867.8996
	Fax:
	Mobile:
	Email: hunter.mouse@brewerfire.com

System Control Unit

Manufacturer: Ansul	Discharge Time:	Predischage Delay:
Model Number: R-102	Install Date: 12/15/2020	
Software Version:	Version Date: 12/15/2020	
Location: Kitchen 64974421	Current Protection:	

Systems Inspected

System Type	Protected Area	Devices
Kitchen	Range Hood-	8


Inspection Summary

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Auxiliary	2	25.00%	2	100.00%	2	100.00%	0	0.00%
Container	3	37.50%	3	100.00%	3	100.00%	0	0.00%
Controls	1	12.50%	1	100.00%	1	100.00%	0	0.00%
Initiating	2	25.00%	2	100.00%	2	100.00%	0	0.00%
Totals	8	100%	8	100.00%	8	100.00%	0	0.00%

Certification

Company: Brewer and Company

Inspector: Hunter Mouse



Signed: Sep 23, 2025

Building: Tidewater - USARC 99th -
Bridgeport WV010

Contact: Jennifer Bailie

Hunter Mouse Certifications

Certification Type	Number
Getz Equipment Innovators Certification- NFPA 10 Portable Fire Extinguishers	
NFPA 80 (2016) Online Training Certification	Swing Door/Fire Door
OSHA 10-Hour Construction	
West Virginia Fire Protection Worker – Fire Extinguisher Technician	
West Virginia License - Low Voltage Electrician	

INSPECTION & TESTING

Generated by: BuildingReports.com

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other . Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Building: Tidewater - USARC 99th - Bridgeport WV010

Device Type	Location	Service	Time	Date
PASSED				
Kitchen Range Hood-				
CO2 Tank	Kitchen	Tested	9:05:31 AM	09/23/2025
Control Panel	Kitchen	Tested	9:05:23 AM	09/23/2025
Cylinder	Kitchen	Tested	9:05:39 AM	09/23/2025
Fusible Link	Kitchen	Tested	9:06:02 AM	09/23/2025
Nozzle	Kitchen	Tested	9:05:46 AM	09/23/2025
Pull Station	Kitchen	Tested	9:05:16 AM	09/23/2025
Relay	Kitchen	Tested	9:07:09 AM	09/23/2025
Relay	Kitchen	Tested	9:08:11 AM	09/23/2025

AUXILIARY FUNCTIONS TESTING

Generated by: BuildingReports.com

The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.

Building: Tidewater - USARC 99th - Bridgeport
WV010

All Protected Areas

Type	Location	Comment	ScanID	Simulated
PASSED				
Relay				
Programmable	Kitchen	Passed	000111	<input type="checkbox"/>
Programmable	Kitchen	Passed	000222	<input type="checkbox"/>

TIME, TEMPERATURE & LEVEL TESTING

Generated by: BuildingReports.com

The Time, Temperature, & Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level. Items are grouped by Passed or Failed/Other.

Building: Tidewater - USARC 99th - Bridgeport
WV010

All Protected Areas

Type	Location	Comment	Sec	Deg	Lvl	ScanID
PASSED						
Fusible Link						
K	Kitchen	Passed	n/a	360F	n/a	64974425

AGENT CONTAINER REPORT

Generated by: BuildingReports.com

A container of stored agent to be used in case of a fire emergency.

Building: Tidewater - USARC 99th - Bridgeport
WV010

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank

Location		Manufacturer		Model #	Type		Serial #	ScanID
Kitchen		Ansul		101-20 part 17492	High Pressure			64974422
Hydro Date	Capacity	Gross Weight	Actual Weight	Tare Weight	Lvl. Indicator	Liquid Level	Puff Tested	
02/18/2021					<input type="checkbox"/>		<input type="checkbox"/>	

Cylinder

Location		Manufacturer		Model #	Type		ScanID
Kitchen		Ansul			Wet Chemical		64974423
Supply		Size		Weight	Total Flow Points Used		Pressure
Master		3 gal					
Method		UL 300?		Mfg. Date	Recharged Date		Hydro Date
Mechanical-Automatic		<input checked="" type="checkbox"/>		02/18/2021	02/18/2021		02/18/2021

Nozzle

Location		Manufacturer		Model #	Qty	Install Date	ScanID
Kitchen		Ansul			6	12/15/2008	64974424

KITCHEN SYSTEM

Generated by: BuildingReports.com

A pre-engineered wet chemical fire-extinguishing system that discharges wet chemical from fixed nozzles and piping by means of expellant gas or a dry chemical fire-extinguishing system that discharges dry chemical from fixed nozzles or hand hose lines by means of expellant gas.

Building: Tidewater - USARC 99th - Bridgeport
WV010

All Protected Areas

KITCHEN RANGE HOOD-

CO2 Tank

Location		Manufacturer		Model #	Type	Serial #		ScanID
Kitchen		Ansul		101-20 part 17492	High Pressure			64974422
Hydro Date	Capacity	Gross Weight	Actual Weight	Tare Weight	Lvl. Indicator	Liquid Level		Puff Tested
02/18/2021					<input type="checkbox"/>			<input type="checkbox"/>

Control Panel

Location		Manufacturer		Model #	Serial #		ScanID
Kitchen		Ansul		R-102	S240084		64974421
Predischage Delay		Discharge Time		Protection Type	Software Version		Software Date
							12/15/2020

Cylinder

Location		Manufacturer		Model #	Type	Serial #		ScanID
Kitchen		Ansul			Wet Chemical			64974423
Supply		Size		Weight	Total Flow Points Used		Pressure	
Master		3 gal						
Method		UL 300?		Mfg. Date	Recharged Date		Hydro Date	
Mechanical-Automatic		<input checked="" type="checkbox"/>		02/18/2021	02/18/2021		02/18/2021	

Fusible Link

Temp	Location		Quantity	Type	Manufacturer	Model #	ScanID
------	----------	--	----------	------	--------------	---------	--------

KITCHEN RANGE HOOD- (continued)**Fusible Link** (continued)

Temp (continued)	Location	Quantity	Type	Manufacturer	Model #	ScanID
360F	Kitchen	3	K	Ansul		64974425

Nozzle

Location	Manufacturer	Model #	Qty	Install Date	ScanID
Kitchen	Ansul		6	12/15/2008	64974424

Pull Station

Location	Manufacturer	Model #	Type	Cover	Serial #	ScanID
Kitchen	Ansul		Cable	No Cover		64974420

Relay

Location	Manufacturer	Model #	Type	Serial #	ScanID
Kitchen	Ansul		Programmable		000111
Kitchen	Ansul		Programmable		000222

INVENTORY & WARRANTY REPORT

Generated by: BuildingReports.com

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Building: Tidewater - USARC 99th - Bridgeport WV010

Device or Type	Category	% of Inventory	Quantity
CO2 Tank	Container	12.50%	1
Control Panel	Controls	12.50%	1
Cylinder	Container	12.50%	1
Fusible Link	Initiating	12.50%	1
Nozzle	Container	12.50%	1
Pull Station	Initiating	12.50%	1
Relay	Auxiliary	25.00%	2

Type	Qty	Model #	Description	Install Date
------	-----	---------	-------------	--------------

IN SERVICE - 90 DAYS - 1 YEAR

Kitchen Range Hood-

Fusible Link	1		K	10/01/2024
Relay	2		Programmable	10/01/2024

IN SERVICE - 3 YEARS TO 5 YEARS

Kitchen Range Hood-

CO2 Tank	1	101-20 part 17492	High Pressure	02/18/2021
Control Panel	1	R-102		12/15/2020
Cylinder	1		Wet Chemical	02/18/2021
Pull Station	1		Cable	12/15/2020

IN SERVICE - 15 YEARS TO 25 YEARS

Kitchen Range Hood-

Type	Qty	Model #	Description	Install Date
IN SERVICE - 15 YEARS TO 25 YEARS (continued)				
Kitchen Range Hood- (continued)				
Nozzle	1			12/15/2008