

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

LIGHTING, OUTSIDE

SITE AND BLDG #: **Saugerties 128**




**MECHANIC
SIGNATURE:**

DATE: **3/15/2022**

LOCATION/RM #: **site** **WO#** **16404** **ASSET #** **10855**

START TIME: **0500**

FINISH TIME: **0600**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
TO BE PERFORMED AT EACH INSPECT					
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		     	
2	Schedule and coordinate work with operating personnel.	✓		     	
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		     	
1	Open and tag switch.	✓		     	
2	Inspect visual condition of wiring. Look for evidence of overheating.	✓		     	
3	Check for proper light operation.	✓		 	
4	Test operation of automatic switches/ time clock/ photocells if applicable.	✓		 	
5	Inspect light pole and mounting devices for deficiencies.	✓		 	
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓		 	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Cm ticket
opens on
previous pms

11 lights in military
equipment lot out