

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**ENERGY RECOVERY VENTILATOR**

SITE AND BLDG #: **Schenectady 060**MECHANIC  
SIGNATURE:DATE: **3/8/2023**LOCATION/RM #: **oms** WO# **21330** ASSET # **10505**START TIME: **1315**FINISH TIME: **1345**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check all moving components for proper lubrication. Apply lubrication where required.	✓		
2	Check dampers to ensure they open and close properly.	✓		
3	Check all fan belts for wear, tension, alignment, and dirt accumulation.	✓		
4	Check fan wheels and fasteners for oil and dust accumulation and clean as necessary.	✓		
5	Check, clean, and/or replace both internal and external filters as necessary.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**