

Not Cert.


WO# 5879

10/30

## Argent Inspections

### Form AI-03

### Boiler Inspection Report

Inspection Date 10/30/2018	Certificate Issued No	Expiration Date	Prepared for Inspection Yes	Next Watersides/Firesides 2019/2019	Next Strength Test 0
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness					
Customer USARC Dover DE-001			Boiler Location Name and/or Building Number Boiler Room		
Address 44 New Street			Boiler Location Address		
City Dover	State DE	Zip 19904	City	State	Zip 0
National Board #	Jurisdiction #	Property # #2	Boiler Use Closed Heating Loop	Fuel Type Natural Gas	
Manufacturer Bosch		Model # GB312 240	Serial # 2530-203-30002-7747014551	Year Built	
Capacity 881,000 BTU/HR	Design Pressure 50 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Bosch	Burner Manufacturer Bosch	
Number of Safety Valves 1	Combustion Efficiency % CO2 ppm CO % Excess O2				Flue Gas Temperature Degrees F
	Valve Manufacturer Watts	Size 3/4"	Set Pressure 50 psi	Capacity 881,000 BTU/HR	Lift Pressure Hand
Valve 1					Reseat Pressure Sat
Valve 2					
Valve 3:					
Valve 4:					
Safety Devices Tested Blocked Intake, Blocked Flue, Return Temperature Sensor, Outlet Temperature Sensor, Heat Exchanger Temperature Sensor, Operating Temperature Control, Heat Exchanger Temperature Control, Low Water Control, Safety Relief Valve.					
Reason(s) for Declining Certification There are no remote emergency shutdowns at the points of egress to this boiler room as required by NBIC Part 2.5.3.2					
Comments Firesides were viewed and found to be in good condition. There were no leaks from the watersides and no evidence of flame impingement.					
Inspector Commission 13314	Inspector Craig H. Bennett	Signature 			
Attachments No	Technical Manager Pages	Signature 