

PASSED


WO # 5881

10/30

## Argent Inspections

Form AI-03


### Boiler Inspection Report

Inspection Date 10/30/2018	Certificate Issued Yes	Expiration Date 10/30/2018	Prepared for Inspection Yes	Next Watersides/Firesides 2019/2019	Next Strength Test 0
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness					
Customer USARC Cape Henlopen DE-002			Boiler Location Name and/or Building Number		
Address 1137 Savannah Road			Boiler Location Address		
City Lewes	State DE	Zip 19958	City	State	Zip 0
National Board # Cast AI 2 DE-002	Jurisdiction #	Property # #2	Boiler Use Closed Heating Loop	Fuel Type Liquid Propane	
Manufacturer Weil-McLain	Model # Ultra 750			Serial #	Year Built
Capacity 750,000 BTU/HR	Design Pressure 80 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Weil McLain	Burner Manufacturer Weil McLain	
Number of Safety Valves 1	Combustion Efficiency % CO2 ppm CO % Excess O2				Flue Gas Temperature Degrees F
Valve 1	Valve Manufacturer Watts	Size 3/4"	Set Pressure 50 psi	Capacity 1,325,000 BTU/HR	Lift Pressure Hand
Valve 2					Sat
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Low Gas Pressure Switch, High Gas Pressure Switch, Operating Temperature Control, Outlet Temperature Sensor, Inlet Temperature Sensor, High Stack Temperature Switch, Safety Relief Valve, and Emergency Disconnect.					
Reason(s) for Declining Certification					
Comments Firesides were viewed and found to be in serviceable condition. Model # was unknown so a description of preparation for watersides inspection was not forwarded. Waterside inspection shall be performed in 2019. Watersides inspection is required every third year per the Guidace (Unified Facilities Criteria 3-430-07)					
Inspector Commission 13314	Inspector Craig H. Bennett	Signature 			
Attachments	Technical Manager	Signature			
No Pages	Craig H. Bennett				

Passed

WO# 5881

10/30

Argent Inspections				
Form AI-08		Boiler Inspection Certificate		
Expiration Date 10/30/2018	Inspection Date 10/30/2018	Next Watersides/Firesides 2019/2019	Next Strength Test 0	National Board # Cast AI 2 DE-002
Customer USARC Cape Henlopen DE-002		Manufacturer Weil-McLain	Year Built	
Building #		Serial #	Property # #2	Jurisdiction #
Pressure Allowed 80 psi	Capacity 750,000 BTU/HR	Safety Valves 1	Programmer Mfr Weil McLain	Burner Mfr Weil McLain
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness			Fuel Type(s) Certified to Use <input type="checkbox"/> Coal <input type="checkbox"/> Natural Gas <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood <input type="checkbox"/> Heavy Fuel Oil	
Commission # 13314	Inspector: Craig H. Bennett	Signature 		

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER