not Cert. WO# 5883 10/31

Argent Inspections

Form AI-03

Boiler Inspection Report

Inspection Date	Certificate Issued	Expiration Date	Prepared for Inspection	Next Watersides/Firesides	Next Strength Test
10/31/2018	No		Yes	2019/2019	0

Inspection Type(s) Performed

☑ Internal ☐ Watersides ☑ Firesides ☐ External/Operational ☐ Pressure Test ☐ Strength ☐ Tightnes

Customer	Boiler Location Name and/or Building Number
AFRC Newark DE-007	Boiler Room
Address	**Boiler Location Address**
1001 Ogletown Road	

City	State	Zip	City	State	Zip
Newark	DE	19711			0

National Board #	Jurisdiction #	Property #	Boiler Use	Fuel Type
109874		B-2	Closed Heating Loop	Natural Gas

Manufacturer	Model #	Serial #	Year Built
Fulton	PHW-2000		

Capacity	Design Pressure	Operating Pressure	Programmer Manufacturer	Burner Manufacturer
2,000,000 BTU/HR	160 psi	20 psi	Fulton	Fulton

Number of Safety Valves	Combustion Efficiency			Flue Gas Temperature
1	% CO2	ppm CO	% Excess O2	Degrees F

	Valve Manufacturer	Size	Set Pressure	Capacity	Lift Pressure	Reseat Pressure
Valve 1	Apollo	/4"	100 psi	2,336,000 BTU/HR	Hand	Sat
Valve 2						
Valve 3:						
Valve 4:						

Safety Devices Tested

Reason(s) for Declining Certification

Boiler would not lite off for proving of safety devices.

Comments

Per NBIC Part 1 3.5.3 (b) a manually operated remote shutdown must be located at each point of egress from the boiler room.

Inspector Commission	Inspector	Signature
13314	Craig H. Bennett	Craig H. Bennett
Attachments	**Technical Manager**	**Signature**
No Pages	Craig H. Bennett	Craig H. Bennett