


Argent Inspections

WO# 5902

Form AI-03

Boiler Inspection Report

Inspection Date 10/25/2018	Certificate Issued No	Expiration Date	Prepared for Inspection Yes	Next Watersides/Firesides 2019/2019	Next Strength Test 0
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness					
Customer USARC Rockville MD-021			Boiler Location Name and/or Building Number Boiler Room		
Address 1850 Baltimore Road			Boiler Location Address		
City Rockville	State MD	Zip 20737	City	State	Zip 0
National Board # ASME A1 USARC MD-02	Jurisdiction #	Property # #1	Boiler Use Closed Heating Loop	Fuel Type Natural Gas	
Manufacturer Weil-McLain		Model # Ultra 550	Serial #	Year Built Unknown	
Capacity 550,000 BTU/HR	Design Pressure 80 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Weil McLain	Burner Manufacturer Weil McLain	
Number of Safety Valves 1	Combustion Efficiency % CO2 ppm CO % Excess O2			Flue Gas Temperature Degrees F	
	Valve Manufacturer	Size	Set Pressure	Capacity	Lift Pressure
Valve 1	Watts	1/4"	80 psi	1,400,000 BTU/HR	Hand
Valve 2					
Valve 3:					
Valve 4:					
Safety Devices Tested Safety Devices Proven: Flame Rod, Flame Rod Igniter, Combustion Air Switch, Low Water Lock Out, Temperature Rise Control, High Temperature Limit, High Gas Pressure Switch, Low Gas Pressure Switch, Safety Relief Valve.					
Reason(s) for Declining Certification The altitude gage on this boiler required by ASME CSD-1 HG-611 does not function properly and must be repaired to comply with the Guidance. The emergency stop that must be installed in this space must secure all boilers in the space.					
Comments This condensing boiler creates acidic waste after the condensing process is complete. This waste must be neutralized before being sent to sanitary sewer (plumbing Code).					
Inspector Commission 13314	Inspector Craig H. Bennett	Signature 			
Attachments No Pages	Technical Manager Craig H. Bennett	Signature 