


W# 5908

Argent Inspections

Form AI-03

Boiler Inspection Report


Inspection Date 10/25/2018	Certificate Issued Yes	Expiration Date 10/25/2019	Prepared for Inspection Yes	Next Watersides/Firesides /2019	Next Strength Test 0
Inspection Type(s) Performed					
<input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness					
Customer USARC Alexandria VA-002			Boiler Location Name and/or Building Number		
Address 6901 Telegraph Road			Boiler Location Address		
City Alexandria		State VA	Zip 22310	City State Zip	
National Board #	Jurisdiction #	Property # C	Boiler Use Closed Heating Loop	Fuel Type Natural Gas	
Manufacturer Burnham		Model # ALP 3099F-1L07	Serial # 65179293	Year Built 2010	
Capacity 399,000 BTU/HR	Design Pressure 50 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Burnham	Burner Manufacturer Burnham	
Number of Safety Valves 1	Combustion Efficiency % CO ₂ ppm CO % Excess O ₂			Flue Gas Temperature Degrees F	
	Valve Manufacturer Conbraco	Size 3/4"	Set Pressure 50 psi	Capacity 805,000 BTU/HR	Lift Pressure Hand
Valve 2					
Valve 3:					
Valve 4:					
Safety Devices Tested Combustion Air Switch, Operating Temperature Control, Temperature Rise Lockout, Safety Relief Valve.					
Reason(s) for Declining Certification					
Comments Firesides were viewed via fiber-optic boroscope. Moderate accumulation of particulates in combustion chamber. Combustion chamber must be cleaned at manufacturers recommended intervals to maintain the advantage of the condensing feature of this boiler. Boiler was inspected by request of the activity per Unified Facilities Criteria 4-430-07 1-5 Applicability.					
Inspector Commission 13314	Inspector Craig H. Bennett	Signature 			
Attachments No	Technical Manager Pages	Signature Craig H. Bennett			

WO # 5908

Argent Inspections

Form AI-08

Boiler Inspection Certificate

Expiration Date 10/25/2018	Inspection Date 10/25/2018	Next Watersides/Firesides 1/2019	Next Strength Test 0	National Board #
Customer USARC Alexandria VA-002		Manufacturer Burnham	Year Built 2010	
Building #		Serial # 65179293	Property # C	Jurisdiction #
Pressure Allowed 50 psi	Capacity 399,000 BTU/HR	Safety Valves 1	Programmer Mfr Burnham	Burner Mfr Burnham
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness			Fuel Type(s) Certified to Use <input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood <input type="checkbox"/> Heavy Fuel Oil	
Commission # 13314	Inspector: Craig H. Bennett	Signature 		

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER