

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

KITCHEN HOOD

ACTIVITY AND BLDG #: **Albany 001**

LOCATION/RM #: **kitchen** WO#

ASSET #

**MECHANIC
SIGNATURE:**

6/24/2022

DATE:

START TIME: **0930**

FINISH TIME: **0945**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean all accessible surfaces thoroughly.	✓		
2	Check all louvers and dampers. If dampers must be moved to ensure complete cleaning, ensure they will be marked and returned to their original position to prevent unbalancing the system.	✓		
3	Clean and/or replace filters, if applicable.	✓		
4	Ensure unit is operating properly, not any deficiencies.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: