

# PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

## UNIT HEATER, HOT WATER

SITE AND BLDG #: **Schenectady 060**MECHANIC  
SIGNATURE:DATE: **6/2/2022**LOCATION/RM #: **building** WO#

ASSET #

START TIME: **0915**FINISH TIME: **0945**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule shutdown with operating personnel.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check valve for full stroke operation in both directions, if applicable.	✓		
2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	✓		
3	Clean the coil with vacuum cleaner.	✓		
4	Comb the fins as needed.	✓		
5	Clean all fans and motors.	✓		
6	Check operation of controls and safeties.	✓		
7	Lubricate as required.	✓		
8	Check all motors, belts, pulleys, shafts, etc. for alignment.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**