

EMTech dba / Energy Management Technologies, LLC
5 Hemlock Street
Latham, NY 12110
Phone # (518) 783-7810

Invoice

Date	Invoice #
10/8/2021	7068

Bill To

CMI Management, Inc.
PM / 99th - Region 2
5285 Shawnee Road Suite #510
Alexandria, VA 22312

Project	P.O. No.	Terms		Due on receipt
19801 Army Reserve T & M by Location	CSS# 30721	Due Date		10/8/2021
Description	Qty	Rate	Serviced	Amount
Completed time and material work as quoted per proposal for the Saugerties Army Reserve Site.	1	806.00	8/13/2021	806.00T
"Repair faulty York supply and return water temperature sensors."				
SALES TAX: <i>If deducting sales tax from invoice, please include your tax exempt certificate with payment.</i>				
For Assistance or Questions Please Contact Office Phone: (518) 783-7810 Extension 113 Service Dept. (518) 631-6004 Fax (518) 783-2079				
<i>Thank you for your business!</i>				
Subtotal \$806.00				
Sales Tax (8.0%) \$64.48				
Total \$870.48				
Payments / Credits \$0.00				
Balance Due \$870.48				



ENERGY MANAGEMENT TECHNOLOGIES, LLC

5 HEMLOCK STREET

LATHAM, NEW YORK 12110

518.783-7810

FAX: 518.783-2079

PROPOSAL

May 28, 2021

CMI Management
Attn: Joe Bayne

Original CSS# 30721
EMTech Initial Field Report# 6490

Subject: No Air Conditioning at Saugerties Location

Scope of Service:

EMTech proposes to supply all labor and material needed to complete the following

- Remove faulty York supply and return water temperature sensors
- Replace both sensors with new
- Check for proper temperature
- Test operation

For the above work, we quote: \$806.00.....Eight Hundred and Six Dollars.

Any and all taxes are not included.

The above is broken down as follows: \$372.00 **Labor**
 \$280.00 **Material**
 \$154.00 **Travel**

Thank you for continuing to include EMTech on your energy team. As always, we look forward to working with you. Please feel free to contact for any questions or concerns you may have on this project.

Sincerely,

Jenna Caligaris
Service Coordinator



Energy Management Technologies, LLC
Service 518-631-6004 Main 518-783-7810 Fax 518-783-2079

7068

FIELD REPORT

Location Name / Address <i>CMI Sungate ARC</i>	Bill To	Date <i>8/13/21</i>
Contact / Phone	EMTech Contract #	Customer PO #
	Technician Code <input type="checkbox"/> Contract <input type="checkbox"/> T & M <input checked="" type="checkbox"/> Quoted <input type="checkbox"/> Warranty <input type="checkbox"/> Sales Support <input type="checkbox"/> Material Sale Only	

Problem Description:

<input type="checkbox"/> Electrical Shock Hazards	WORK PERFORMED <i>Replaced Sensors. Restart & ck operation</i>		
<input type="checkbox"/> Confined Space			
<input type="checkbox"/> Inadequate Ventilation			
<input type="checkbox"/> Water/Oil/Other Liquids on Floor			
<input type="checkbox"/> Trip or Fall Hazards			
<input type="checkbox"/> Fire or Explosive Hazards			
<input type="checkbox"/> Site Checked			

Did Refrigerant Activity occur?	
<input type="checkbox"/> Yes If yes, a Refrigerant Activity	
<input type="checkbox"/> No Report Must be completed	

Source	Qty	Part #	Description		PO #
<input type="checkbox"/> CS Customer Supplied	<i>VP</i>	<i>2</i>	<i>chilled water sensors</i>		<i>70685ARC</i>
<input type="checkbox"/> PC Procurement/Cash					
<input type="checkbox"/> TS Truck					
<input type="checkbox"/> TP EMTech Parts					
<input type="checkbox"/> VP Vendor Purchase					
<input type="checkbox"/> Sm Recovery Sys					
<input type="checkbox"/> Lg Recovery Sys					
<input type="checkbox"/> Vacuum Pump					
<input type="checkbox"/> Welder					
<input type="checkbox"/> Tube Brush Unit					
<input type="checkbox"/> Technology Charge					
<input type="checkbox"/> Fuel Charge					
<input type="checkbox"/> Environment Fee					
<input type="checkbox"/> Trip Charge					
<input type="checkbox"/> Pressure Washer					
<input checked="" type="checkbox"/> Mileage					
<input checked="" type="checkbox"/> Misc. Supplies					

LABOR							
Date	Name	DDC (Tech)	MS (Mech)	MS (Chiller)	Reg	Over Time	Double Time
<i>8/13/21</i>	<i>Daniel Ogle</i>		<i>X</i>		<i>2 1/2</i>		

Follow-up Required? Yes No Describe

Customer Signature	Date	PO #
--------------------	------	------