


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

LIGHTING, OUTSIDE

SITE AND BLDG #: **Saugerties 128**

**MECHANIC
SIGNATURE:**



DATE: **7/12/2023**

LOCATION/RM #: **site** **WO#** **23107** **ASSET #** **10855**

START TIME: **0450**

FINISH TIME: **0600**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)			
		YES	NO	SPECIAL INSTRUCTIONS			
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.						
2	Schedule and coordinate work with operating personnel.						
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.						
TO BE PERFORMED AT FACILITY							
1	Open and tag switch.						
2	Inspect visual condition of wiring. Look for evidence of overheating.						
3	Check for proper light operation.						
4	Test operation of automatic switches/time clock/ photocells if applicable.						
5	Inspect light pole and mounting devices for deficiencies.						
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.						

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

**8 pathway and 2 flag lights out, 4 pov lights,
2 oms lights out**