

# **PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST** **EMERGENCY EXIT SIGNS AND WALL PACKS**

ACTIVITY AND BLDG #: **Plattsburgh 054**

MECHANIC  
SIGNATURE: 

DATE: **8/11/2021**

LOCATION/RM #: **building** WO# 

ASSET # 

START TIME: **1020**

FINISH TIME: **1120**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer’s recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs			<div>1 light in maintenance bay a year out. bad board</div> 
2	Push test buttons and observe light operation. Note any units that do not operate properly.			
3	Clean exterior with dry cloth.			
4	For Exit lights check for proper arrow direction.			
5	Make and/or recommend any needed repairs.			



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**