



Hyde-Stone
Mechanical
Contractors

Invoice

HYDE-STONE MECHANICAL CONTRACTORS INC.
PLATTSBURGH

Service at: **US ARMY RESERVE - PL**
5363 PERU STREET
ROUTE 9
PLATTSBURGH, NY 12901

Mail Remittance to:

Hyde-Stone Mechanical Contractors, Inc.
22962 Murrock Circle
Watertown, NY 13601 (315) 788-1300

Bill To: **CMI MANAGEMENT**

PM / 99TH - REGION 2
5285 SHAWNEE ROAD
SUITE #510
ALEXANDRIA, VA 22312

Invoice Date: 12/20/2018

Invoice No.: 91101

Customer ID: 10343

Payment Terms: Net 30 Days

Your PO Number:

Service Requested Quoted - High Limit - Doug (Approved by Customer on 12/13/18 - LF)///

WO Number: **89686** **PL- HEATING**

Call Resolution

12/13/2018 CSS 16676 Hot Water Repair

While on site installing parts, our technician determined that your Hatco Unit, Model # S-12, Serial # 1404229507 will need a new high limit and T&P valve. The pricing shown below covers labor and materials required to do this work. Please call me at extension #236 if you have any questions. Thank you.

12/18/2018 Hatco Unit,
Model # S-12,
Serial # 1404229507
Shut off power and water. Drained tank.
Removed cover and removed old high limit.
Doped up new bushing and installed high limit probe.
Wired in control and turned water back on. Tested unit operation.

Call Completed 12/18/2018 Technician HOWARD; DOUGLAS E.

Date	Regular	OT	DT
12/11/2018	1.00		
12/18/2018	2.00		
Total:	3.00		

Parts Not in Inventory

352.18

Subtotal:	352.18
* Sales Tax:	28.17
Total Due:	380.35

* EX

To Do Items





Hyde-Stone Mechanical Contractors

SERVICE REPORT

WORK ORDER:

89686

DATE: 12/18/2018

CUSTOMER: US ARMY RESERVE - PL (AR#:10333)
STREET: 5363 PERU STREET, ROUTE 9
CITY: PLATTSBURGH, NY 12901
CONTACT: RON VOGT - CELL

DESCRIPTION: Quoted - High Limit - Doug (Approved by Customer on 12/13/18 - LF)///
CALL TYPE: PLATTSB - HEATING
TROUBLE REPORTED: PL- HEATING
WORK PERFORMED: Pulled old valve and replaced with new T&P 3" relief valve. Turned on water and power and again purged tank.
Let tank reach temp and adjusted for dishwasher. 140f. (HOWARD; DOUGLAS E. on Dec 11, 2018)
CSS 16676 Hot Water Repair

While on site installing parts, our technician determined that your Hatco Unit, Model # S-12, Serial # 1404229507 will need a new high limit and T&P valve. The pricing shown below covers labor and materials required to do this work. Please call me at extension #236 if you have any questions. Thank you. (FRASHER; LINDA L. on Dec 13, 2018)

Hatco Unit,
Model # S-12,
Serial # 1404229507

Shut off power and water. Drained tank.

Removed cover and removed old high limit.

Doped up new bushing and installed high limit probe.

Wired in control and turned water back on. Tested unit operation. (HOWARD; DOUGLAS E. on Dec 18, 2018)

PARTS

QUANTITY	DESCRIPTION
1	VEHICLE CHARGE
1	T & P RELIEF VALVE
1	02.16.116.00 - T-STAT LIMIT MECH WET

LABOR

DATE	LABOR	TECHNICIAN/DESC
12/18/2018	2 (PW-REG)	HOWARD; DOUGLAS E. (Service Repair)
12/11/2018	1 (SD)	HOWARD; DOUGLAS E. (Service Repair)

IS JOB COMPLETE? Yes

Customer

Name: _____

Date: 12/18/2018 01:44 PM

Comments:

Technician


Name: DOUG HOWARD

Date: 12/18/2018 01:44 PM

Comments:


Email

Customer Signature



A handwritten signature in black ink, appearing to read 'John Doe', is written over a horizontal line.

Technician Signature



A handwritten signature in black ink, appearing to read 'John Doe', is written over a horizontal line.