

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FILTER REPLACEMENT

SITE AND BLDG #: ny024-208

**MECHANIC
SIGNATURE:** **Ramon V**

DATE: 6-4-2021

LOCATION/RM #: 217 WO# 13009-13011

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.			
2	Initial and Date Filter (if disposable)			
3	Initial and Date Yellow Maintenance Tag (if applicable)			
ASSET #	SIZE	QTY	NOTES/ ACTIONS	
9610	20x20x2	6	replace	
9612	16x25x2	2	replace	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: