

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, HOT WATER
baseboard hot water

SITE AND BLDG #: ny024-356LOCATION/RM #: WO# 13248 ASSET # 9709MECHANIC
SIGNATURE: Ramon V DATE: 6-11-2021

START TIME: FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	check		
2	Schedule shutdown with operating personnel.			
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	check		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for full stroke operation in both directions, if applicable.	check		
2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	check		
3	Clean the coil with vacuum cleaner.	check		clean baseboard and check for water leaks
4	Comb the fins as needed.	check		
5	Clean all fans and motors.	check		
6	Check operation of controls and safeties.	check		
7	Lubricate as required.	check		
8	Check all motors, belts, pulleys, shafts, etc. for alignment.	check		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: