

June checklist 2021

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, INFRA-RED, RADIANT, GAS

SITE AND BLDG #: ny024-358

MECHANIC
SIGNATURE: Ramon V

DATE: 6-2-2021

LOCATION/RM #: WO# 13255 ASSET # 9774

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	check		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	check		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	For gsa/oil heaters: 1. Remove access panels if applicable. 2. Check the fire box liner or refractory for cracks and leaks. 3. Check all gas lines for leaks. Repair as needed.	check		
2	Clean dirt from heater, vaccuming is preferred.	check		
3	Check operation of gas valve.	check		
4	Check for gas leaks.	check		
5	Check operation of thermostat.	check		
6	If applicable, replace primary air intake filter.	check		
7	As needed, clean spark electrode and reset gap, replace if necessary.	check		
8	Inspect flue pipe and connections.			
9	If applicable, inspect and clean outside air blower and blower intake.	check		
10	Inspect unit for proper operation.	check		
11	Inspect unit for overall condition and recommend for replacement or other needed repairs.	check		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: