

**INSPECTION, TESTING, AND CERTIFICATION OF WORK**  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA168

Date of Visit: 02/27/2018

Contractor Personnel on Site:

4. Joseph Benz

4. \_\_\_\_\_

5. \_\_\_\_\_

5. \_\_\_\_\_

6. \_\_\_\_\_

6. \_\_\_\_\_

**Work Performed:**

**Inspection, Testing, and Certification**

5. Backflow Prevention Testing (Qty 5) (Annual)

6. WO 2329, 2406, 2316, 2393

7. \_\_\_\_\_

8. \_\_\_\_\_

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Joseph Benz Date: 02/27/2018

Signed: 

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: SGT Nicholas Vaccaro Date: 2/27/2018

Signed: 

E-Mail: nicholas.p.vaccaro.mil@mail.mil

MANUF. WILKINS MODEL 975XL  
SERIAL # 1359614 SIZE 1/2"  
TEST DATE 2/27/18 TIME 11:06A  
TESTER ASSE5429 LINE PSI 50  
CK1 8.6 CK2 8.2 VALVE OPEN 3.0

MANUF. WATTS MODEL 009

SERIAL # 12037 SIZE 3"

TEST DATE 2/27/18 TIME 11:00A

TESTER ASSE5429 LINE PSI 60

CK1 8.4 CK2 7.0 VALVE OPEN 2.2

MANUF. APOLLO MODEL RP40  
SERIAL # 170560 SIZE 2"  
TEST DATE 2/27/18 TIME 12:00P  
TESTER ASSE5429 LINE PSI 60  
CK1 7.4 CK2 6.0 VALVE OPEN 2.6

MANUF. WILKINS MODEL 975XL  
SERIAL # 2990239 SIZE 3/4"  
TEST DATE 2/27/18 TIME 11:30A  
TESTER ASSE5429 LINE PSI 50  
CK1 9.0 CK2 8.4 VALVE OPEN 2.8

MANUF. Flmcs MODEL 400055 SERIAL # 121666 SIZE 6 " TEST DATE 2/27/18 TIME 11:20A TESTER ASSESS429 LINE PSI 120 CK1 10.0 CK2 8.2 VALVE OPEN 3.0