

WO #2317 Asset #7252

Pennsylvania American Water
 Attention: Cross Connection Department:
 2699 Stafford Ave, Scranton, PA 18505-3608
 Phone: 1-877-290-1769 Email: paw.cc@amwater.com Fax: 1-570-341-3296

Contract Account Number: 210034289252

Premise Number: 9240030436

Location Information

Service For: Commander 99Th Arcom
 Service Address: 410 Miller Ave
 New Castle, PA 16101-1451

Device Information

BFA Type: DOUBLE CHECK VALVE ASSEMBLY

Manufacturer: Apollo/Conbraco

Manuf. Serial Number: J3287

Water Meter Number: J3297

Model: DCLF4A

Size: 2 1/2"

Type of Service:

Domestic ☒

Fire ☐

Irrigation ☐

Location of Device: AFTER METER

New Assembly ☐

Isolation ☒

Containment ☐

Replaces Serial No: _____

TEST MEASUREMENTS

	DC		RP	PVB/SVB
	Check Valve #1	Check Valve #2	Pressure Diff. Relief Valve	Air Inlet
Initial				
Date: 2-5-18	Held at 2.4 PSID	Held at 5.3 PSID	Opened at _____ PSID	Opened at _____ PSID
Time: 08:40	Closed Tight ☒	Closed Tight ☐ Leaked ☐	Did Not Open ☒	Did Not Open ☐
Line pressure: 87	Leaked ☐	#2 Shut Off Valve Closed Tight? Yes ☐ No ☐	N/A	Check Valve Held _____ PSID
Final				
Date: _____	Held at _____ PSID	Held at _____ PSID	Opened at _____ PSID	Opened at _____ PSID
Time: _____	Closed Tight ☐	Closed Tight ☐ Leaked ☐	Did Not Open ☐	Did Not Open ☐
Line pressure: _____	Leaked ☐	#2 Shut Off Valve Closed Tight? Yes ☐ No ☐		Check Valve Held _____ PSID
AIR GAP	Measured vertical inches above overflow		Supply Size Diameter	

COMMENTS (including maintenance performed):

TESTER INFORMATION

INITIAL Tester Name

PASS ☒ Phone #

FAIL ☐ Signature

Testing Equipment Calibration Date:

FINAL Tester Name

PASS ☐ Phone #

FAIL ☐ Signature

Testing Equipment Calibration Date:

Company

Email Address

Certified Tester Number:

Testing Equipment Serial Number:

Company

Email Address

Certified Tester Number:

Testing Equipment Serial Number:

BACKFLOW TEST FORM - TO BE COMPLETED BY A STATE CERTIFIED OR QUALIFIED TESTER
 The above report is certified to be true at the time of the test
 Please return completed form by 01/30/2018