



DESIGN • INSTALL • SERVICE

SINCE 1893

BILL TO	Mail Remittance to:		
CMI MANAGEMENT PM / 99TH - REGION 2 5285 SHAWNEE ROAD ALEXANDRIA VA 22312	Hyde-Stone Mechanical Contractors, Inc. 22962 Murrock Circle Watertown, NY, 13601 TF: 1-866-401-9053		
JOB LOCATION	Invoice Number : W18442 Invoice Date : Oct 31/21 Customer Code : USARMY054 Terms : 30 Customer PO : 32932 Work Order # : 21-0010402		
Description	Qty	Price	Total
Work Performed			
CSS: 32932 FACID: NY054 Type: Urgent Repair Requested: Overhead heating unit in the drill hall is leaking at the fittings. Troubleshoot and repair.			
10/18/2021 pw Army Reserve -- drill hall Modine Model v78s01 Serial 05010493 Checked in with management. Received report. Went to unit and found bucket catching water. Looked at plumbing and found couplers loose by a quarter turn each. Tightened and inspected rest of plumbing. Found header tube inside unit to be severely corroded. Not leaking yet but will need to be replaced within a couple of years. Work order complete			

Materials

Total Materials 0.00

Labor

Total Labor 220.00

Travel

Total Travel 50.00

Other

Total Other 0.00

Subtotal	270.00
Sales Tax	
Total Invoice	270.00

Thank You for your business.

If you have any questions, please call Tammy Parisian
Direct: 315-755-2278 Office: 315-788-1300 (x231)
tparisian@hyde-stone.com