

Backflow Specialists, Inc.

Commercial - Residential
Licensed Master Plumber
NYS Certified Testers

CUSTOMER INVOICE

63 Greeley Ave., Sayville, NY 11782-2604
Tel: 631-567-8382 Fax: 631-567-5919

www.backflowspecialists.com
info@backflowspecialists.com

Location Name:

Location Name:			
Name	Service Date: 9/21/23		
Street Address	Tech Name: Mike B		
City, State Zip	WO#:		
Contact Name:		Contact Tel:	() -
Terms: Due Upon Receipt		Comments	

TEST RESULTS SUBMITTED TO AUTHORITIES UPON RECEIPT OF PAYMENT.

We performed the following backflow device testing:

	Mfg	RPZ	DCV	Model	Size	Serial #	Pass	Fail	Pressure	Diff. Press.	Line	Price
									Drop 1st Ck	RV-Open'd	PSI	
1)	WILKINS	X		9751	2	3425565	X		8.8	2.4	60	
	Meter #: Reading:						Location: Mgmt Shop					
2)	WILKINS	V		909	3	190857	X		7.4	2.2	58	
	Meter #: Reading:						Location:					
3)	WILKINS	X		375	6	158504	X		5.6	2.4	62	
	Meter #: Reading:						Location: Brick Shop					
4)	WILKINS	X		375	6	196130	X		9.0	2.2	70	
	Meter #: Reading:						Location: Brick Shop					
5)												
	Meter #: Reading:						Location:					
											Subtotal	\$

We performed the following repairs:

Subtotal \$

Remarks:

	Sales Tax	\$
	Pay This Amount	\$
BALANCES DUE OVER 60 DAYS WILL BE CHARGED INTEREST.		Received by: <i>[Signature]</i>