

## Additional Funding Request

PA166	CSS # 13983	WO 4890	ASSET # No Asset #
Description of Repairs	CLEAN DAMAGED AREAS OF EPMD ROOF MAKE NECESSARY REPAIRS CLEAN UP AND DISPOSE OF DEBRIS		
Diagnosis: Initial Work Order	Urgent- Repair EPDM roof over kitchen. Large puddle of water under roofing material due to large tear. Need to remove water, inspect/repair decking, replace and seal patched area, inspect and repair other seams as necessary. Preferred vendor-		
Explanation of Additional Costs for Repairs	N/A		
Additional Labor Cost to Perform Repairs	\$ 1280.00(16hrs @ 80.00/hr)		
Additional Material Cost to Perform Repairs	\$365.28		
Shipping	N/A		
Total Cost of Repair	\$1654.28		