

**Hyde-Stone Mechanical**

Contractors, Inc. 22962 Murrock Circle  
 Watertown, NY 13601  
 315-788-1300 Fax 315-788-9646

**To:** CMI MANAGEMENT  
 PM / 99TH - REGION 2  
 5285 SHAWNEE ROAD  
 ALEXANDRIA VA 22312  
**Attn:** JOE BAYNE - CMI

**Work Address:** US ARMY RES 054/CMI  
 ROUTE 9, 5363 PERU STREET  
 PLATTSBURGH NY  
 12901

**QUOTATION**

**Quote #:** 0000000797-000  
**Quote Type:** Work Order  
**Reference:** 7065/PAUL  
**Cross Ref:**  
**Work Order:** n/a  
**Customer:** USARMY054  
**Terr/sale:** HSE  
**Current Date:** Jun 14, 2021  
**Expiry Date:** N/A

| Code              | Description | Quantity | UOM | Price | Total |
|-------------------|-------------|----------|-----|-------|-------|
| CSS28918/WO 12846 |             |          |     |       |       |

We were asked to check the emergency lights. Our technician made the following notes:

06/10/2021 pw

Checked in with Sgt Griffin. Inspected 6 emergency lights, found 2 to be good and 4 to be bad. Quote to be submitted for repair work.

The pricing shown below covers labor and materials and required to do this work. The diagnostic call is being invoiced separately. Please call me at extension #236 if you have any questions. Thank you.

|      |                   |      |       |        |        |
|------|-------------------|------|-------|--------|--------|
| TECH | Service Tech.     | 6.00 | Hours | 110.00 | 660.00 |
| N/A  | EMERGENCY LIGHTS  | 3.00 | EA    | 307.20 | 921.60 |
| N/A  | EMERGENCY LIGHT   | 1.00 | EA    | 196.00 | 196.00 |
|      | ENVIRONMENTAL FEE | 1.00 |       | 12.00  | 12.00  |

**Sub Total**

1,789.60

**Total Quotation**

1,789.60