

Tina Lee

From: Tina Lee
Sent: Thursday, July 28, 2022 1:12 PM
To: Thomas Devlin (thomas.j.devlin@usace.army.mil); Richard Hicks
Subject: REVISED QUOTE additional funds needed for D021 WO# 17789 (IDIQ)
Attachments: MD021 WO 17789 Quote 1061.pdf; REVISED Quote_No_1135 MD021 WO 17789(1).pdf

Tom,

There was a price increase due to Relay that had burned up.

Revised: \$3,622.14 +CE \$217.33 = \$3,839.47

Original: \$2,601.69 +CE \$156.10 = \$2,757.79

\$1,021.45 +CE \$61.23 = \$1081.68

Additional Needed = \$1,081.68

See Email Pictures in email string below

Thank you...Make it a Great Day!!!

Tina M. Lee
Work Orders Service Desk / 99th - Region 5
5285 Shawnee Road, Suite 510
Alexandria, VA 22312
703-738-5302
Tina.lee@cmimgmt.com
99R5.Service@cmimgmt.com

This message (including any attachments) contains confidential or privileged information intended for a specific individual and purpose, and is protected by law. If you are not the intended recipient, please notify the sender at (703) 738-5300. Any disclosure, copying, or distribution of this message, or the taking of any action based on it, is strictly prohibited.


From: Lindsay Ruby <lindsay@sandsmidatlantic.com>
Sent: Thursday, July 28, 2022 9:36 AM
To: Richard Hicks <richard.hicks@cmimgmt.com>
Cc: Tina Lee <Tina.Lee@cmimgmt.com>
Subject: [EXTERNAL]Re: MD021 WO# 17789

CAUTION: This email has been received from outside of CMI - Use caution before clicking on links, opening attachments, or responding.

Rick,

Brian was onsite Wednesday and found the control relay was burnt up. I have added the relay/harness to the quote and have it attached.







Use for TRAULSEN Part No. **PD36120**


\$439.95

Sign up for price alert

Qty:

ADD TO CART

ADD TO WISHLIST





G702320762



Adapter - Harness To Main

Zoro #: G702320762 Mfr #: 333-60225-00



Tap to zoom

Help us improve our product images

\$77.08

zoro.com

On Thu, Jul 28, 2022 at 8:01 AM Richard Hicks <richard.hicks@cmimgmt.com> wrote:

Lindsay was this completed ?

Work Order	Description	Site	Location / Fac. ID	Site Code	Amount	CLIN	CSS #	Target Finish
17789	Repair breaker to Kitchen Refrigerators, Keeps tripping off	99REG5	MD021-01	24825	2757.79	4003-AK	837	

Thanks,

Rick

Rick Hicks

Project Manager Region 5

CMI Management Inc.

5285 Shawnee Road Suite #510

Alexandria,VA 22312

703-738-5301

Richard.Hicks@cmimgmt.com

--

Lindsay Ruby

S&S Mechanical

"Feeling Good About What We Do"

Phone: 301-574-1555

Fax: 301-574-1558

www.sandsmidatlantic.com

lindsay@sandsmidatlantic.com